


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction SW 1/4 NW 1/4 SW 1/4	Section number 36	Township number T 23 S	Range number R 1-W E/W
2. Distance and direction from nearest town or city: FROM NEWTON COWPATACK 1/2 S 1/2 W 3/4 S Street address of well location if in city:			3. Owner of well: Betty Grosh R.R. or street: RR #1 City, state, zip code: NEWTON KANS 67114			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 			
5. Type and color of material			From	To	6. Bore hole dia. 10 in. Completion date 5-29-79 Well depth 51 ft.	
CLAY			0	25	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
COURSE SAND			25	30	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
CLAY			30	35	9. Casing: Material plst Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 31 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200	
COURSE GRAVEL			35	50	10. Screen: Manufacturer's name SUNFLOWER plst pipe Type 200 Dia. 5" Slot/gauze 1/16 Length 20' Set between 31 ft. and 51 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.	
SHALE			50	51	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-1/2	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 10 ft. below land surface Date 5-29-79	
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 10 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date ____	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade	
					15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
					16. Nearest source of possible contamination: ft. 60' Direction NW Type OTHER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 10205412 12 Volts 230 Length of drop pipe 40 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MARTIN Supply 362 Business name License No. Address 500 W 14th St Newton Signed Bruce Schmidt Date 6-8-79 Authorized representative	
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						