

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stafford	Fraction NE 1/4 1/4	Section number 7	Township number T 23 S	Range number R 11 W
2. Distance and direction from nearest town or city: 7 mi. E. of Stafford, KS			3. Owner of well: John Brock R.R. or street: Stafford, Kansas 67578 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 6/10/76 Well depth 104 ft.		
		Well No. 1 Test Hole No. 1-76		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material Stl. Height: Above or below 18 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.91 lbs./ft. Dia. 16 in. to 65 ft. depth Wall Thickness: inches or Dia. 16 in. to 65 ft. depth gage No. .219		
Sandy soil		0	2	10. Screen: Manufacturer's name Doerr Metal Products Type Stl. Dia. 16 " Slot/gauze 1/8 " Length 40 ' Set between 64 ft. and 104 ft. ft. and 104 ft.		
Sandy clay		2	14	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 1/4		
Fine to coarse sand w/med gravel		14	56	11. Static water level: 6.25 ft. below land surface Date 6/10/76 mo./day/yr.		
Brown clay with cemented sand (hard)		56	60	12. Pumping level below land surfaces: 30.6 ft. after 4 hrs. pumping 800 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1000 g.p.m.		
Med. to coarse sand & med. to coarse gr.		60	104	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 		
Brown clay		104	105	14. Well head completion: Steel Plate <input type="checkbox"/> Pitless adapter 18 inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 11 ft.		
				16. Nearest source of possible contamination: ft. 2600 Direction N Type Farm Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 12" KL HP 50 Volts 460 Length of drop pipe 80 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name License No. Address Wichita, Kansas Signed John Brock Date 6-14-76 Authorized representative		
18. Elevation:	19. Remarks:			20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5