


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Stafford	Township name	Fraction SW/SW¹/₄	Section number 24	Town number 23	Range number 13	
Distance and direction from nearest town or city: St. John - DRL 4 North, 3 East of Hudson, Ks. Street address of well location if in city:				3 Owner of well: H-30 Drilling Co. Address: 200 North Main St. Wichita, Ks.			
Locate with "X" in section below: N  W E S 1 Mile		Sketch map:		4 Well depth: <u>80</u> ft. Date of completion <u>2-12-75</u> Well diameter <u>8</u> in.			
2 Type and color of material		From		To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
		Sandy top soil		0 3		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Oil Field Water Supply	
		Clay		3 7		7 Casing: Material <u>pvc</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Digm. Weight <u>160</u> lbs./ft. <u>4</u> in. to <u>60</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No <u> </u> in. to <u> </u> ft. depth	
		Sandy clay		7 10		8 Screen: Manufacturer <u>R & B</u> Type <u>pvc</u> Dio. <u>4</u> Slot gauze <u>1/16</u> Length <u>20</u> Set between <u>60</u> ft. and <u>80</u> ft. Fittings: <u>3/4-3/8-1/16</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>Co #3</u>	
		Sand & gravel		10 35		9 Static water level: <u>8</u> ft. below land surface Date <u>2-12-75</u>	
		Clay		35 36		10 Pumping level below land surfaces: <u>20</u> ft. after <u>1</u> hrs. pumping <u>75</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>200</u> g.p.m.	
		Sand & gravel		36 45		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
		Clay		45 46		12 Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade	
		Sand & gravel		46 76		13 Well grouted? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neot cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Depth: From <u> </u> ft. to <u> </u> ft.	
		Clay		76 80		14 Nearest source of possible contamination: ft. <u>95</u> Direction <u>SW</u> Type <u>oil well</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
(use a second sheet if needed)				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosencrantz-Bemis 134</u> Business name License No. Address <u>Great Bend, Ks.</u> Signed <u>Fredia Dodson</u> Date <u>2-17-75</u> Authorized representative			
16 Remarks: elevation <p style="text-align: center;">well will be pulled and plugged</p> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							