USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Stafford	SW 1/4 SW 1/4 SW1/4	26	T 23 S	R 13 (W)

2. Distance and direction from nearest town or city:
1½ mi. East of St. John, KS
Street address of well location if in city:

3. Owner of well: Kansas State University
R.R. or street: AG-Engineering Dept.
City, state, zip code: Manhattan, KS 66502

4. Locate with "X" in section below: Sketch map:

N
NW NE
W E
SW SE
x
S
1 Mile
1 Mile

6. Bore hole dia. 9 in. Completion date 6-1-76
Well depth 50 ft.

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
X Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material Styrene Height: (Above) or below
Threaded ___ Welded X Surface 12 in.
RMP ___ PVC ___ Weight 1.5 lbs./ft.
Dia. 5 in. to 40 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 200#

5. Type and color of material	From	To
Top ~~XXXXX~~ soil	0	3
Sandy clay	3	11
Sand, gravel & clay streak at 16'	11	31
XX Yellow clay	31	34
Sand & gravel	34	50

(Use a second sheet if needed)

10. Screen: Manufacturer's name Jess & Lowell
Type Styrene 200 Dia. X 5"
Slot/gauze 1/8 Length 10'
Set between 40 ft. and 50 ft.
___ ft. and ___ ft.
Gravel pack? Yes Size range of material 3/8-200

11. Static water level: mo./day/yr.
10'4" ft. below land surface Date 5-11-76

12. Pumping level below land surfaces: N/C
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date ___

14. Well head completion:
__ Pitless adapter 12 Inches above grade

15. Well grouted? Yes
With: X Neat cement ___ Bentonite ___ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
NONE KNOWN
ft. ___ Direction ___ Type ___
Well disinfected upon completion? ___ Yes X No

17. Pump: __ Not installed
Manufacturer's name Berkeley Pump Co.
Model number 4AM-11 HP ½ Volts 230
Length of drop pipe 60 ft. capacity 12 g.p.m.
Type:
X Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

18. Elevation:

Topography:
__ Hill
__ Slope
__ Upland
__ Valley

19. Remarks: This is one of two wells drilled in almost the exact location.

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Clarke Well & Eq., Inc. 185
Business name License No.
Address Great Bend, KS
Signed J. W. Clarke Date 6-1-76
Authorized representative

T 23 R 13 E Sec 26 1/4 SW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023