USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Stafford	NE 1/4 SE 1/4 SE 1/4	2 9	T 23 S	R 13 E/W

2. Distance and direction from nearest town or city:
½ mile Northwest of St. John, KS
Street address of well location if in city:

3. Owner of well: Keith Fairchild
R.R. or street: Route 3
City, state, zip code: St. John, KS 67576

4. Locate with "X" in section below: Sketch map:

N
NW NE
W E
SW SE X
S
1 Mile
1 Mile

6. Bore hole dia. 24 in. Completion date 4-7-77
Well depth 103 ft.

7. __ Cable tool __ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored X Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
X Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material steel Height: Above or below
Threaded ___ Welded X Surface 12 in.
RMP ___ PVC ___ Weight 30.3 lbs./ft.
Dia. 16 in. to 37 ft. depth Wall Thickness: inches or
Dia. 16 in. to 91 ft. depth gage No. 7 ga.

10. Screen: Manufacturer's name 1 - Doerr
2 - Cook
Type Double-slot Dia. 16"
Slot/gauze 1/8" Length 1-36' & 2-10'
Set between 1- 37 ft. and 47 ft. 1-91' &
2- 47 ft. and 57 ft. 103'
Gravel pack? yes Size range of material 3/8-200

11. Static water level: mo./day/yr.
12 ft. below land surface Date 9-2-76

12. Pumping level below land surfaces: N/C
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
___ Yes X No Date ___

14. Well head completion:
___ Pitless adapter 12 Inches above grade

15. Well grouted? yes
With: X Neat cement ___ Bentonite ___ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: FIELD
ft. ___ Direction ___ Type ___
Well disinfected upon completion? ___ Yes X No

17. Pump: ___ Not installed
Manufacturer's name Peerless Pump
Model number 12MB-2 HP 60 Volts --
Length of drop pipe 90 ft. capacity 900 g.p.m.
Type:
___ Submersible X Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

5. Type and color of material	From	To
Top soil & brown clay	0	6
Sand & gravel	6	56
Sand & gravel & clay streaks	56	64
Limestone & gravel streaks	64	70
Sandy clay & sandstone & limestone streaks	70	89
DAkota drift & gravel streaks	89	101
Dakota clay	101	103

(Use a second sheet if needed)

18. Elevation:

Topography:
___ Hill
___ Slope
___ Upland
___ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Clarke Well & Eq., Inc. 185
Business name License No.
Address Great Bend, KS 67530
Signed [signature] Date 4-12-77
Authorized representative

T 23 R 13 E/W Sec 29 1/4 NE 1/4 SE 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023