


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Stafford		Fraction SW C 1/4 N 1/4 NW 1/4		Section number 35	Township number T 23 S	Range number R 13 E (W)
2. Distance and direction from nearest town or city: 1 mile East of St. John, KS Street address of well location if in city:				3. Owner of well: Richard Spare R.R. or street: Route 1 City, state, zip code: St. John, KS 67576		
4. Locate with "X" in section below: 				6. Bore hole dia. <u>9</u> in. Completion date <u>3-22-78</u> Well depth <u>65</u> ft.		
				7. Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ ☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary		
				8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other		
				9. Casing: Material <u>Styrene</u> Height: Above or below Threaded ☐ Welded ☒ Surface <u>12</u> in. RMP ☐ PVC ☐ Weight <u>1.5</u> lbs./ft. Dia. <u>5</u> in. to <u>55</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>200</u>		
5. Type and color of material				10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>Styrene 200</u> Dia. <u>5"</u> Slot gauge <u>1/8</u> Length <u>10'</u> Set between <u>55</u> ft. and <u>65</u> ft. Gravel pack? <u>yes</u> Size range of material <u>3/8-200</u>		
				11. Static water level: _____ mo./day/yr. <u>12' 2"</u> ft. below land surface Date <u>3-22-78</u>		
Top soil				12. Pumping level below land surfaces: <u>N/C</u> _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. ☐ Yes ☒ No Date _____		
Brown clay				14. Well head completion: _____ ☐ Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <u>yes</u> With: ☒ Neat cement ☐ Bentonite ☐ Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Sand & gravel & thin clay streak at 23'				16. Nearest source of possible contamination: <u>FIELD</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? ☒ Yes ☐ No		
				17. Pump: ☒ Nat installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Equip., Inc. 185 Business name License No. _____ Address <u>Great Bend, KS 67530</u> Signed <u>[Signature]</u> Date <u>3-23-78</u> Authorized representative		
18. Elevation:		19. Remarks:				
Topography: ____ Hill ____ Slope ____ Upland ____ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023