


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stafford	Fraction 1/4 c 1/4 sw 1/4	Section number 13	Township number T 23 S R 14 E	Range number 14
2. Distance and direction from nearest town or city: 2 1/2 - W 3 1/4 - N of St. John, Ks. Street address of well location if in city:				3. Owner of well: Lloyd McCandless R.R. or street: Rt. 3 City, state, zip code: St. John, Ks. 67576		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 29 in. Completion date 6-21-76 Well depth 97 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy top soil		0	18	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 97 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7		
Brown sandy clay		18	33	10. Screen: Manufacturer's name Doerrs Type steel Dia. 16 Slot/size 3/16 Length 32 Set between 65 ft. and 97 ft. ft. and <input type="checkbox"/> ft.		
Fine sand and gravel		33	35	Grovel pack? <input checked="" type="checkbox"/> Size range of material 3/4-3/8		
Sand and gravel clean coarse loose		35	95	11. Static water level: <input type="checkbox"/> mo./day/yr. 30 ft. below land surface Date 3-10-76		
Light gray clay		95	105	12. Pumping level below land surfaces: 65 ft. after 1 hrs. pumping 700 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 750 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 3-10-76		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 4 mi Direction NE Type gas well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Jacuzzi Model number 4-12ms HP 60 Volts 460 Length of drop pipe 80 ft. capacity 650 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name Great Bend, Ks. License No. Address Sandy Kilgore Date 6-19-79 <input checked="" type="checkbox"/> Signed: Sandy Kilgore Authorized representative		
19. Remarks:						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5