USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Stafford	SE 1/4 SE 1/4 SW 1/4	16	T 23 S	R 14 E (W)

2. Distance and direction from nearest town or city:
7½ miles Northwest of St. John, KS
Street address of well location if in city:

3. Owner of well: Ward Beaver
R.R. or street: Route 3
City, state, zip code: St. John, KS 67576

4. Locate with "X" in section below: Sketch map:

N
NW NE
W E
SW SE
X
S
1 Mile 1 Mile

6. Bore hole dia. 9 in. Completion date 2/21/79
Well depth 56 ft.

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material Styrene Height (Above) or below
Threaded ___ Welded X Surface 12 in.
RMP ___ PVC ___ Weight 1.5 lbs./ft.
Dia. 5 in. to 46 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 200

5. Type and color of material	From	To
/ Sandy top soil	0	6
Sandy yellow clay	6	23
Sand	23	27
Sandy clay & sand	27	40
Yellow clay	40	42
Sand & gravel	42	48
Sand & gravel - ~~XXXX~~ Coarse	48	54
Sand	54	58
Yellow clay	58	60
(Use a second sheet if needed)		

10. Screen: Manufacturer's name Jess & Lowell
Type Styrene 200 Dia. 5"
(Slot) gauze 1/8" hole Length 10'
Set between 46 ft. and X 56 ft.
___ ft. and ___ ft.
Gravel pack? Yes Size range of material 3/8-200

11. Static water level: mo./day/yr.
15.3 ft. below land surface Date 2/21/79

12. Pumping level below land surfaces: N/C
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date ___

14. Well head completion:
__ Pitless adapter 12 Inches above grade

15. Well grouted? Yes
With: X Neat cement ___ Bentonite ___ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: Field
ft. ___ Direction ___ Type ___
Well disinfected upon completion? X Yes ___ No

17. Pump: X Not installed
Manufacturer's name ___
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.p.m.
Type:
__ Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

18. Elevation:
Topography:
__ Hill
__ Slope
__ Upland
__ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Clarke Well & Eq., inc. 185
Business name License No.
Address Great Bend, KS 67530
Signed O.W. Clarke Date 2/22/79
Authorized representative

23 T 14 R (W) E 16 Sec SESESW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023