

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stafford	Fraction 1/4 1/4 CNW 1/4	Section number 16	Township number T 23 S	Range number R 14 EW
2. Distance and direction from nearest town or city: 9 miles NW of St. John Street address of well location if in city:				3. Owner of well: Ward Beaver R.R. or street: Route 3 City, state, zip code: St. John, KS 67576		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>24</u> in. Completion date <u>6-4-76</u> Well depth <u>96</u> ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>30.3</u> lbs./ft. Dia. <u>16</u> in. to <u>40</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gauge No. <u>7 ga.</u>		
sand		0	7	10. Screen: Manufacturer's name <u>Doerr</u> Type <u>Double-slot</u> Dia. <u>16"</u> <u>slot</u> gauze <u>1/8"</u> Length <u>56"</u> Set between <u>40</u> ft. and <u>96</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>3/8-200</u>		
sandy clay, sand & soft sandstone		7	38	11. Static water level: _____ mo./day/yr. <u>21'</u> ft. below land surface Date <u>5-17-76</u>		
sand, gravel, & thin clay streaks		38	51	12. Pumping level below land surfaces: <u>N/C</u> _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
yellow clay		51	54	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
sand & gravel		54	80	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
cemented gravel, yellow clay, & loose gravel				15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
streaks		80	87	<u>NONE KNOWN</u> 16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
sand & gravel		87	95	17. Pump: Manufacturer's name <u>Berkeley</u> Not installed Model number <u>1202M-4</u> HP <u>80</u> Volts <u>--</u> Length of drop pipe <u>70</u> ft. capacity <u>900</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				18. Elevation:		
19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq. Inc. 185 Business name <u>nd</u> License No. _____ Address <u>Great Bend, KS 67530</u> Signed <u>C.W. Clarke</u> Date <u>6-22-76</u> Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5