

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction 1/4 1/4 CNE 1/4	Section number 21	Township number T 23 S R 15 E W
2. Distance and direction from nearest town or city: 7 mi. Southeast of Zook, Kansas Street address of well location if in city:				3. Owner of well: Darrell W. Clarke R.R. or street: 709 Patton Road City, state, zip code: Great Bend, KS 67530	
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 24 in. Completion date 9-24-75 Well depth 86 ft.
Top soil			0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Gray & brown clay			3	28	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Brown clay & sand			28	45	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.3 lbs./ft. Dia. 16 in. to 56 ft. depth Wall Thickness: inches or Dia. 16 in. to 86 ft. depth gage No. 7 ga.
Brown clay & gravel streaks			45	55	10. Screen: Manufacturer's name Doerr & Johnson Division (J.D.) Irr. Type Double-slot & Dia. 16" Slot gauge 1/8 Length 28' Set between Doerr-56 ft. and 69 ft. J.D.--69 ft. and 84 ft. Gravel pack? Yes Size range of material 3/8-200
Sand & gravel			55	83	11. Static water level: 25 ft. below land surface Date 9-24-75 mo./day/yr.
Brown XXX clay			83	86	12. Pumping level below land surfaces: N/C ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
					13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____
					14. Well head completion: ____ Pitless adapter 12 inches above grade
					15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? ____ Yes XXX No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: ____ Hill ____ Slope ____ Upland ____ Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name Great Bend, KS License No. ____ Address Great Bend, KS Signed D.W. Clarke Date 9-24-75 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5