


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Pawnee	Township name	Fraction SE 1/4	Section number 25	Town number 23 S	Range number 15 W
Distance and direction from nearest town or city: 4 miles North 3 East of Macksville			3 Owner of well: Mr. Ted Guyer Macksville, Kansas			
Street address of well location if in city:			Address:			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 74.80 ft. Date of completion 4/12/75 Well diameter 30 in.
						5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
						7 Casing: Material Stl Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 16 in. to 46.80 ft. Depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> No
2			Type and color of material	From	To	8 Screen: Manufacturer Doerr Type Steel Dia. 16 " Slot/gauze 1/8 Length 28 ' Set between 46.8 ft. and 74.8 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8 x 3/8
			Top soil	0	2	9 Static water level: 12 ft. below land surface Date 4-9-75
			Brown clay	2	10	10 Pumping level below land surfaces: 46 ft. after 4 hrs. pumping 700 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 700 g.p.m.
			Sandy gray clay	10	25	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____
			Fine sand	25	29	12 Well head completion: <input type="checkbox"/> Pitless adapter 12 <input checked="" type="checkbox"/> Inches above grade
			Sandy gray clay	29	35	13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Depth: From 0 ft. to 10 ft.
			Fine sand & clay	35	47	14 Nearest source of possible contamination: ft 10,000 Direction South Type oil well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
			Fine sand	47	52	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 75104K HP 75 Volts ____ Length of drop pipe 60 ft. capacity 700 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			Med. to coarse sand & gravel	52	73 1/2	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co., Inc. 102 Business name License No. Address Wichita, Kansas Signed [Signature] Date 4/14/75 Authorized Representative
			Clay	73 1/2	76	
			(use a second sheet if needed)			
16 Remarks: elevation						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5