


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Pawnee</u>	Fraction <u>C/NW</u> 1/4 1/4 1/4	Section number <u>5</u>	Township number <u>23</u> T S R	Range number <u>16</u> E/W
2. Distance and direction from nearest town or city: <u>6.5 1/4 W 1/4 S of Larned</u> Street address of well location if in city:				3. Owner of well: <u>Dave Titus</u> R.R. or street: <u>Rt. 2</u> City, state, zip code: <u>Great Bend, Ks.</u>		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile				Sketch map: 		
5. Type and color of material				From	To	6. Bore hole dia. <u>29</u> in. Completion date <u>8-5-76</u> Well depth <u>85</u> ft.
<u>Sandy Top Soil</u>				<u>0</u>	<u>2</u>	7. Cable tool <u>Rotary</u> Driven <u> </u> Dug <u> </u> Hollow rod <u> </u> Jetted <u> </u> Bored <u> </u> Reverse rotary <u> </u>
<u>Clay</u>				<u>2</u>	<u>8</u>	8. Use: <u>Domestic</u> <u>Public supply</u> <u>Industry</u> <u>Irrigation</u> <u>Air conditioning</u> <u>Stock</u> <u>Lawn</u> <u>Oil field water</u> <u>Other</u>
<u>Fine Sand</u>				<u>8</u>	<u>30</u>	9. Casing: Material <u>Steel</u> Height <u>Above</u> or <u>below</u> Threaded <u> </u> Welded <u> </u> Surface <u>18</u> in. RMP <u> </u> PVC <u> </u> Weight <u> </u> lbs./ft. Dia. <u>16</u> in. to <u>85</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>7</u>
<u>Clay</u>				<u>30</u>	<u>32</u>	10. Screen: Manufacturer's name <u>Doers</u> Type <u>Steel</u> Dia. <u>16</u> Slot/size <u>3/16</u> Length <u>28</u> Set between <u>57</u> ft. and <u>85</u> ft. ft. and <u> </u> ft. Gravel pack? <u> </u> Size range of material <u>1/2 3/4 1 1/2</u>
<u>Fine Sand</u>				<u>32</u>	<u>36</u>	11. Static water level: <u>21</u> ft. below land surface Date <u>7-16-76</u> mo./day/yr.
<u>Clay</u>				<u>36</u>	<u>37</u>	12. Pumping level below land surfaces: <u>21</u> ft. after <u>1</u> hrs. pumping <u>700</u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>800</u> g.p.m.
<u>Good Sand</u>				<u>37</u>	<u>42</u>	13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u> </u> No Date <u>7-28-76</u>
<u>Clay</u>				<u>42</u>	<u>44</u>	14. Well head completion: <u> </u> Pitless adapter <u> </u> inches above grade
<u>Sand</u>				<u>44</u>	<u>45</u>	15. Well grouted? <u> </u> With: <u> </u> Neat cement <u> </u> Bentonite <u> </u> Concrete <u> </u> Depth: From <u>2</u> ft. to <u>16</u> ft.
<u>Clay</u>				<u>45</u>	<u>46</u>	16. Nearest source of possible contamination: ft. <u>12</u> m Direction <u>W</u> Type <u>Septic tank</u> Well disinfected upon completion? <u> </u> Yes <u> </u> No
<u>Good Clean Sand</u>				<u>46</u>	<u>70</u>	17. Pump: <u> </u> Not installed Manufacturer's name <u>WBR</u> Model number <u>SCM12</u> HP <u>10</u> Volts <u> </u> Length of drop pipe <u>70</u> ft. capacity <u>700</u> g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other
<u>Good Clean Sand & Gravel</u>				<u>70 1/4</u>	<u>85</u>	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosencranz - Bemis 134</u> Business name License No. <u> </u> Address <u>Great Bend, Ks.</u> Signed <u>Fredie Rodden</u> Date <u>9/30/76</u> Authorized representative
<u>Hard Blue Rock</u>				<u>85</u>	<u>90</u>	
(Use a second sheet if needed)						
18. Elevation: <u>2050</u> Topography: <u> </u> Hill <u> </u> Slope <u> </u> Upland <u> </u> Valley		19. Remarks: <u>26260</u> <u>23 16 5 NBX</u>				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5