

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Pawnee		Fraction 1/4 SW 1/4 SW 1/4		Section number 7		Township number T 23 S R 16 NW		Range number			
2. Distance and direction from nearest town or city: 1 3/4 W.				3. Owner of well: Kabbert-Jones, Inc							
Street address of well location if in city: Look, KS				R.R. or street: 830 Sutton Pl.							
				City, state, zip code: Wichita, KS 67202							
4. Locate with "X" in section below:				Sketch map:				6. Bore hole dia. 7 in. Completion date 4-12-77 Well depth 70 ft.			
								7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
								8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other			
								9. Casing: Material _____ Height: <u>Above</u> or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 70 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. Sehl 40			
5. Type and color of material				From		To		10. Screens: Manufacturer's name _____ Type PVC Dia. 4 Slot/gauze 1/16" Length 20 Set between 50 ft. and 70 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"			
Topsoil - Clay				0		30		11. Static water level: _____ mo./day/yr. 22 ft. below land surface Date 4-12-77			
Sand - Clay				30		45		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.			
Sand				45		70		13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____			
								14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade			
								15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
								16. Nearest source of possible contamination: 0.1 ft. 60 Direction S Type Test Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
								17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kelly's Water Well Ser 186 Business name _____ License No. _____ Address R2 Great Bend KS Signed Kelly Price Date 7-7-77 Authorized representative			
18. Elevation:		19. Remarks:									
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley											

T 23
 R 16
 Sec 7 - C S W S W
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5