

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Pawnee		Fraction Center of XX XX SW 1/4	Section number 34	Township number T 23 S	Range number R 16 W
1. Location of well: 12 miles Southeast of Larned, KS Street address of well location if in city:			3. Owner of well: Elmer K. Hahn R.R. or street: Rural Route City, state, zip code: Belpre, KS 67519		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. 8 24 in. Completion date 8-22-77 Well depth 82 ft.		
			7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other		
			9. Casing: Material <u>steel</u> Height <u>Above</u> or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP ___ PVC ___ Weight <u>30.3</u> lbs./ft. Dia. <u>16</u> in. to <u>42</u> ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. <u>7 ga.</u>		
5. Type and color of material			From	To	10. Screen: Manufacturer's name <u>W. A. Brown</u>
Top soil & clay			0	15	Type <u>Double-slot</u> Dia. <u>16"</u>
Fine sand			15	30	Slot/gauze <u>1/8</u> Length <u>40'</u>
Clay			30	33	Set between <u>42</u> ft. and <u>82</u> ft. ___ ft. and ___ ft.
Sand & gravel & thin clay streaks at 40'-60'-64'			33	80	Gravel pack? <u>yes</u> Size range of material <u>3/8-200</u> ft.
					11. Static water level: mo./day/yr. <u>23</u> ft. below land surface Date <u>8-2-77</u>
					12. Pumping level below land surfaces: N/C ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield ___ g.p.m.
					13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date ___
					14. Well head completion: ___ Pitless adapter <u>12</u> Inches above grade
					15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement ___ Bentonite ___ Concrete ___ Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: FIELD fr. ___ Direction ___ Type ___ Well disinfected upon completion? ___ Yes <input checked="" type="checkbox"/> No
					17. Pump: Not installed Manufacturer's name <u>Peerless Pump</u> Model number <u>12MB-3</u> HP <u>60</u> Volts ___ Length of drop pipe <u>70</u> ft. capacity <u>900</u> g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other
(Use a second sheet if needed)					
18. Elevation: Topography: ___ Hill ___ Slope ___ Upland ___ Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name _____ License No. _____ Address <u>Great Bend, KS 67530</u> Signed <u>[Signature]</u> Date <u>8-24-77</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5