

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pawnee	Fraction 1/4 C 1/4 SW 1/4	Section number 35 26	Township number T 23 S	Range number R 17 E/W
2. Distance and direction from nearest town or city: 4-S 4 1/4-E of Garfield, Ks. North into field. Street address of well location if in city:			3. Owner of well: Jerry Penka R.R. or street: RFD City, state, zip code: Larned, Kansas 67550		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 29 in. Completion date 7-7-78 Well depth 66 ft.	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From To		9. Casing: Material steel Height: Above or below 18 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 66 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7	
				10. Screen: Manufacturer's name Doerres & Cook Type steel Dia. 1 1/2 Slot 3/16 Length 22 Set between 44 ft. and 66 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8	
Top soil		0 2		11. Static water level: 21 1/2 ft. below land surface Date 6-28-78	
Clay		2 11		12. Pumping level below land surfaces: 37 ft. after 1 hrs. pumping 600 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 900 g.p.m.	
Sandy clay		11 21		13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 6-28-78	
Clay with some gravel		21 23		14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Sand and gravel		23 62		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Sand & gravel w/little clay mixed		62 66		16. Nearest source of possible contamination: ft. 1000 Direction SE Type septic Well disinfected upon completion? HTH Yes <input type="checkbox"/> No	
White clay		66 80		17. Pump: Manufacturer's name W.L.R. Not installed Model number 4-12CH HP 60 Volts <input type="checkbox"/> Length of drop pipe 50 ft. capacity 750 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Kansas 67530 Signed Sandy K. Rose Date 7-20-78 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5