

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction SE 1/4 NE 1/4 NE 1/4	Section number 23	Township number 23	Range number 17 E/W
2. Distance and direction from nearest town or city: 15 3W 45 200K Street address of well location if in city:				3. Owner of well: Vernon Schartz R.R. or street: Rt. 2 City, state, zip code: Larned, Ks.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 24 in. Completion date 9-24-75 Well depth 69 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From		To		9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 69 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7
						10. Screen: Manufacturer's name Doers Type steel Dia. 16 Slot/gauze 3/16 Length 22 Set between 47 ft. and 69 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8
Top Soil		0		2		11. Static water level: 18 ft. below land surface Date 9-8-75 mo./day/yr.
Brown Clay		2		4		12. Pumping level below land surfaces: 14 ft. after 1 hrs. pumping 800 g.p.m. 14 ft. after 1 hrs. pumping 800 g.p.m. Estimated maximum yield 900 g.p.m.
Tough Gray Clay		4		20		13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 9-9-75 mo./day/yr.
Fine to Med. Sand & Gravel		20		25		14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
Sand & Gravel clean coarse loose		25		37		15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
White Clay		37		39		16. Nearest source of possible contamination: ft. 400 Direction N Type Cornal Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
Sand & Gravel fine to med		39		45		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name WLTR Model number 5-CH-10 HP 60 Volts 115 Length of drop pipe 60 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Sand & Gravel clean coarse loose		45		62 1/2		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz-Bemis 134 Business name Bremt Bend, Ks. License No. Address Larned, Ks. Signed Fredie Dobson Date 9/29/75 Authorized representative
Blue Gray Clay		62 1/2		64		
Sand & Gravel loose, clean dark sand		64		69		
Sand Rock		69		71		
(Use a second sheet if needed)						
18. Elevation: 2075 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 24586 23 17 23 E 5 A				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5