

County: HARVEY		Fraction: SE 1/4 SE 1/4 SE 1/4	Section number: 6	Township number: T 23 S	Range number: R 2
1. Location of well:			2. Distance and direction from nearest town or city: 3W AND 5N OF HALSTEAD, Ks.		
3. Owner of well: Herbert Fast			R.R. or street: R.R. #2		
City, state, zip code: Halstead, Ks.			4. Locate with "X" in section below:		
<div style="text-align: center;">N 1 Mile W E S 1 Mile</div> <div style="text-align: center;">DOMESTIC WELL</div>			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 3-17-78
Top soil			0	2	Well depth 74 ft.
Fine Sand			2	10	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug
Gray Clay			10	13	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Fine gray sand			13	31	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry
Med gray sand			31	54	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock
Brown Clay			54	68	<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine brown sand			68	75	9. Casing: Material <input type="checkbox"/> Height: Above or below
Fine to med brown sand					Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in.
					RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft.
					Dia. 4 in. to 64 ft. depth Wall Thickness: inches or
					Dia. in. to ft. depth Gauge No. 24 70
					10. Screen: Manufacturer's name
					Peerless Plastics
					Type PVC Dia. 4"
					Slot/gauze 1/32 Length 10'
					Set between 64 ft. and 74 ft.
					Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4
					11. Static water level: mo./day/yr.
					12 ft. below land surface Date 3-18-78
					12. Pumping level below land surfaces:
					15 ft. after 1 1/2 hrs. pumping 10 g.p.m.
					ft. after hrs. pumping g.p.m.
					Estimated maximum yield 20-25 g.p.m.
					13. Water sample submitted: mo./day/yr.
					Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
					14. Well head completion:
					Pitless adapter 12 Inches above grade
					15. Well grouted? Yes
					With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete
					Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination:
					ft. None Direction Type
					Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed
					Manufacturer's name
					Model number HP Volts
					Length of drop pipe ft. capacity g.p.m.
					Type:
					<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine
					<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating
					<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:			19. Remarks:		
Topography:			20. Water well contractor's certification:		
<input type="checkbox"/> Hill			This well was drilled under my jurisdiction and this report		
<input type="checkbox"/> Slope			is true to the best of my knowledge and belief.		
<input checked="" type="checkbox"/> Upland			Business name Peterson Irr. Inc. 138A		
<input type="checkbox"/> Valley			Address Box 150 Lindborg, Ks. License No.		
			Signed Mike Peterson Date 4-8-78		
			Authorized representative		