

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction Center of 1/4 NW 1/4	Section number 15	Township number T 23 S	Range number R 2 E
2. Distance and direction from nearest town or city: 3 1/2 NC.			3. Owner of well: WILFORD HOLDER MAN			
Street address of well location if in city: 3/4 W. HALSTEAD KS			R.R. or street: RR I			
			City, state, zip code: HALSTEAD, KANS 67056			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 5-18-77		
				Well depth 117 ft. 77		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material TRANS Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 32 lbs./ft. Dia 16 in. to 117 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 34		
5. Type and color of material		From	To	10. Screen: Manufacturer's name ALBERTA TILE CO.		
Top soil			0 5	Type TRANS. TE Dia. 34		
Clay - Brn.		4	5 13	Slot/gauze 48 Length 39		
" Blk.		3	13 16	Set between 78 ft. and 117 ft.		
Clay Grey		9	16 25	Gravel pack? Yes Size range of material 1/4"		
Sand - Fine			25 32	11. Static water level: 12 ft. below land surface Date 5-18-77		
" - med. w/clay			32 45	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 1000 g.p.m.		
Sand - med.			45 54	13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
Clay - yellow-		2	54 56	14. Well head completion: ____ Pitless adapter ____ Inches above grade		
Sand - Fine			56 69	15. Well grouted? Yes Pudding clay With: ____ Neat cement ____ Bentonite ____ Concrete Depth: From 0 ft. to 10 ft.		
Clay - yellow			69 72	16. Nearest source of possible contamination: House ft. 13 Direction E Type well		
Sand - Fine w/clay			72 75	Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No		
Sand - MED To coarse			75 89	17. Pump: ____ Not installed Manufacturer's name Western Head Pumps Model number 6 m HP 60 Volts 24		
Rock - lime stone			89 90	Length of drop pipe 80 ft. capacity 900 g.p.m.		
Clay - Brn		2	90 98	Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sand - med fine			98 117			
Shale - Blue			117 119			
18. Elevation:		19. Remarks: Cased 117 ft.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				Peterson F&S Inc License No. 138A Business name Address Box 150 Leawards KS Signed Wally Peterson Date 6-1-77 Authorized representative		