


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | | |
|---|--|--|---|--|----------------------------------|--|
| 1. Location of well: | | County HARVEY | Fraction SE 1/4 NW 1/4 NE 1/4 | Section number 18 | Township number T 23 S | Range number R 2 E |
| 2. Distance and direction from nearest town or city: Street address of well location if in city: | | 4 mi NORTH AND 4 mi WEST OF HALSTEAD, KS. | | 3. Owner of well: JOHN E. EWY R.R. or street: R.R. #2 City, state, zip code: HALSTEAD, KS. 67056 | | |
| 4. Locate with "X" in section below: N W E S 1 Mile | | Sketch map:  | | 6. Bore hole dia. 18 in. Completion date 10-26-78 Well depth 76 ft. 7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft. Dia. 4 in. to 56 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 125 | | |
| 5. Type and color of material | | From | | To | | 10. Screen: Manufacturer's name PEERLESS PLASTICS Type PVC Dia. 4" Slot/gauze 1/32 Length 20 Set between 56 ft. and 76 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 14 in |
| Top Soil | | 0 | | 1 | | 11. Static water level: 35 ft. below land surface Date 10-26-78 |
| FINE SAND | | 1 | | 28 | | 12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50-75 g.p.m. |
| GRAY CLAY | | 28 | | 40 | | 13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date |
| GRAY SANDY CLAY | | 40 | | 55 | | 14. Well head completion: Pitless adapter 24 inches above grade |
| FINE SAND AND CLAY | | 55 | | 62 | | 15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. |
| MEDIUM SANDS | | 62 | | 76 | | 16. Nearest source of possible contamination: CATTLE ft. 1000 Direction NORTH Type AND HORSE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| | | | | | | 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |
| | | | | | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON IRRIGATION 138 Business name License No. Address BOX 150 LINDSBURG, KS Signed Mike Peterson Date 11-16-78 Authorized representative |
| 18. Elevation: | | 19. Remarks: | | | | |
| Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley | | | | | | |

23
- 20
18
SE NW NE
1/4 1/4 1/4