


1. Location of well:	County HARVEY	Fraction NE 1/4 SW 1/4 NW 1/4	Section number 19	Township number T 23	Range number S R 2
2. Distance and direction from nearest town or city: 5 miles WEST AND 2 1/2 miles NORTH OF HALSTEAD, KS			3. Owner of well: Ralph Ward R.R. or street: RR #2 City, state, zip code: Halstead, Ks. 67056		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div> 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 10-3-78 Well depth 73 ft.
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material _____ Height Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft. Dia. 4 in. to 6.3 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 2250		
Top soil			0	5	10. Screen: Manufacturer's name Pearless Plastics Type PVC Dia. 4" Slot/gauze 1/16 Length 10' Set between 6.3 ft. and 73 ft. Gravel pack? No Size range of material 1/2 in.
Very fine red sand			5	10	11. Static water level: _____ mo./day/yr. 38 ft. below land surface Date 10-3-78
Med. brown sand			10	20	12. Pumping level below land surfaces: 40 ft. after 15 hrs. pumping 12-15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.
Buff clay			20	50	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Grey clay + fine sand			50	60	14. Well head completion: _____ Pitless adapter 12 Inches above grade
Med. coarse sand			60	73	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 5 ft. to 15 ft.
					16. Nearest source of possible contamination: ft. 100 Direction E Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ HP _____ Volts _____ Model number _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ _____ Jet _____ Reciprocating _____ _____ Centrifugal _____ Other _____
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON IRRIGATION 138 Business name License No. _____ Address Box 150 LINCOLNBURG KS Signed Mike Peterson Authorized representative Date 11-3-78
18. Elevation:	19. Remarks:				
Topography: ____ Hill ____ Slope <input checked="" type="checkbox"/> Upland ____ Valley					