


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | | |
|---|--|-------------------------|--------------------------------------|---|---|--------------|
| 1. Location of well: | | County Harvey | Fraction 1/4 SW 1/4 SW 1/4 | Section number 35 | Township number T 23 S R 2W E/W | Range number |
| 2. Distance and direction from nearest town or city: Street address of well location if in city: 712 West 5th Halstead, KS | | | | 3. Owner of well: Dr. Robert Rate R.R. or street: 712 West 5th City, state, zip code: Halstead, KS | | |
| 4. Locate with "X" in section below: Sketch map:  | | | | 6. Bore hole dia. 11 in. Completion date 11-4-78 Well depth 45 ft. | | |
| 5. Type and color of material | | | | 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary | | |
| | | | | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | | |
| | | | | 9. Casing: Material Styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200 | | |
| | | | | 10. Screen: Manufacturer's name Sunflower plastic Type styrene Dia. 5" Slot/gauze 30 Length 15' Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4-1/8" | | |
| (Use a second sheet if needed) | | | | 11. Static water level: 25 ft. below land surface Date 11-4-78 mo./day/yr. | | |
| | | | | 12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m. | | |
| | | | | 13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____ | | |
| | | | | 14. Well head completion: 12 well seal ____ Pitless adapter ____ Inches above grade | | |
| (Use a second sheet if needed) | | | | 15. Well grouted? yes 1-2 fine sand mix With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft. | | |
| | | | | 16. Nearest source of possible contamination: City ft. 50 Direction North Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No | | |
| | | | | 17. Pump: Not installed Manufacturer's name Jacuzzi Model number 7S4C HP 3/4 Volts 230 Length of drop pipe 40 ft. capacity 18 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| | | | | 18. Elevation: Flat Ground Topography: ____ Hill ____ Slope ____ Upland ____ Valley | | |
| 19. Remarks: | | | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 6-17-79 Authorized representative | | |