


1. Location of well: HARVEY		Fraction SW 1/4 SW 1/4 SW 1/4		Section number 35		Township number T 23 S R 2 E W		Range number	
2. Distance and direction from nearest town or city: Street address of well location if in city: 528 Sweezy Str.				3. Owner of well: Dwight Hershberger R.R. or street: City, state, zip code: Holstead, Kansas 67056					
4. Locate with "X" in section below: 				Sketch map:		6. Bore hole dia. 1 1/2 in. Completion date 7/2/76 Well depth 49 ft.			
5. Type and color of material				From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
								8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
								9. Casing: Material Plastic Height: 0 ft. below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.28 lbs./ft. Dia. 5 in. to 4 1/2 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage Nos. 255	
								10. Screen: Manufacturer's name Robin Tech - own slot Type PVC Dia. 5 1/2 Slot/gauze 10/64 Length 20' Set between 25 ft. and 45 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 - 1/4	
								11. Static water level: 17 ft. below land surface Date 7/2/76 12. Pumping level below land surfaces: 19 ft. after 2 hrs. pumping 20 g.p.m. 48 ft. after 48 hrs. pumping 85 g.p.m. Estimated maximum yield 85 g.p.m.	
(Use a second sheet if needed)								13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
								14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
								15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
								16. Nearest source of possible contamination: City ft. 28 Direction West Type Sanitary Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
								17. Pump: Manufacturer's name Valley Not installed Model number 51804 HP 3/4 Volts 230 Length of drop pipe 30' ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC 125 Business name License No. Address Hession Kansas Signed Paul Bundt Date 7/2 Authorized representative			