

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <u>Edwards</u>	Fraction <u>C 1/4 SE 1/4 SE 1/4</u>	Section number <u>6</u>	Township number <u>T 23</u>	Range number <u>S R 20 E 10</u>
2. Distance and direction from nearest town or city: <u>13-N of Offerle, Ks.</u> Street address of well location if in city:			3. Owner of well: <u>Hadley Polson</u> R.R. or street: <u>none</u> City, state, zip code: <u>Bozell, Ks 67574</u>		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. <u>10</u> in. Completion date <u>7-21-76</u> Well depth <u>95</u> ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material <u>PVC</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <u>4 1/2</u> in. to <u>95</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. <u>237</u>		
			10. Screen: Manufacturer's name <u>Centinied</u> Type <u>PVC</u> Dia. _____ Slot/gauge <u>1/16</u> Length <u>20</u> Set between <u>95</u> ft. and <u>25</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 to 3/8</u>		
			11. Static water level: _____ mo./day/yr. <u>55</u> ft. below land surface Date <u>7-21-76</u>		
			12. Pumping level below land surfaces: <u>65</u> ft. after <u>1</u> hrs. pumping <u>20</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>30</u> g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>7-21-76</u>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: ft. <u>20</u> Direction <u>S</u> Type <u>Road</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosencornz-Bemis 134</u> Business name License No. Address <u>Great Bend, Ks 67530</u> Signed <u>Sandy K. Evans</u> Date <u>6-19-76</u> Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

23 20 06 CSE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5