

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

JBTMOIRE

SF

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Hodgman	Fraction C/NE/NE 1/4 1/4 1/4	Section number 5	Township number 22 S	Range number 22 E/W
2. Distance and direction from nearest town or city: 1 S 1/2 W 1/2 S 1/2 W 1/2 S 1 1/2 W of Hanston				3. Owner of well: Don Houseman R.R. or street: City, state, zip code: Hanston, Ks.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 1/2 in. Completion date 12-8-75 Well depth 88 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 88 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7		
				10. Screen: Manufacturer's name Daeris Type Steel Dia. 16 Slot/gauge 3/16 Length 20 Set between 68 ft. and 88 ft. ft. and <input type="checkbox"/> ft. Grovel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 30 ft. below land surface Date 4-7-75		
				12. Pumping level below land surfaces: 30 ft. after 12 hrs. pumping 375 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 375 g.p.m.		
				13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 4-7-75		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: 1/4 mile Direction NW Type Feed lot Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name WLR Model number 2CM10 HP 10 Volts Length of drop pipe 80 ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosecrantz Bernice 124 Business name License No. Address Great Bend KS Signed Freddie Adams Date 9/20/76 Authorized representative		
19. Remarks: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley 2180 80 2100						

22 22 W 5
 Sec
 1/4 1/4 1/4
 O NENE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5