


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

Hanston
KS

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

AAC

1. Location of well: County Hodgeman		Fraction SW 1/4 NE 1/4 NE 1/4		Section number 10	Township number 23	Range number 22	E/W
2. Distance and direction from nearest town or city: from Hanston, Ks 3 3/4 S - 1/2 W Street address of well location if in city:				3. Owner of well: A. E. Querback R.R. or street: City, state, zip code: Hanston, Ks. 67849			
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 29 in. Completion date _____ Well depth 101 ft. 7-30-79			
5. Type and color of material				From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary	
top soil				0	2	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other	
brown clay				2	31	9. Casing: Material steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP ___ PVC ___ Weight ___ lbs./ft. Dia. 16 in. to 101 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 7	
blue gray sandy clay				31	42	10. Screen: Manufacturer's name Doerrs Type steel Dia. 16" Slot/gauze 3/16 Length 52 Set between 49 ft. and 101 ft. ft. and _____ ft.	
sand and gravel, clean loose				42	65	Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4-3/8-1/2	
clay w/sand streaks				65	79	11. Static water level: _____ mo./day/yr. 30 ft. below land surface Date 6-21-79	
fine sand and gravel				79	80	12. Pumping level below land surfaces: 32 ft. after 1 hrs. pumping 700 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 750 g.p.m.	
sand and gravel, loose, clean				80	93	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes ___ No Date 6-21-79	
gray clay w/sand streaks				93	98	14. Well head completion: ___ Pitless adapter _____ Inches above grade	
fine sand and gravel				98	104	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement ___ Bentonite ___ Concrete Depth: From 0 ft. to 10 ft.	
fire clay				104	107	16. Nearest source of possible contamination: ft. 3/4 mile direction west Type oil well Well disinfected upon completion? ___ Yes ___ No	
BROCK 104' R.P.						17. Pump: ___ Not installed Manufacturer's name W.L.R. Model number 2-14CH HP 20 Volts 460 Length of drop pipe 80 ft. capacity 700 g.p.m. Type: ___ Submersible ___ Turbine <input checked="" type="checkbox"/> ___ Jet ___ Reciprocating ___ Centrifugal ___ Other	
30 74' salt truck						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Box 713 Great Bend, Ks. Signed Freda Anderson Date 8-21-79 Authorized representative	
in Alluvium							
(Use a second sheet if needed)							
18. Elevation: Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley		19. Remarks: 2180 104 2076 TOPD					

23
 22
 10
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5