

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

AAC

Hanston

1. Location of well: County HODGEMAN		Fraction SW NE NE 1/4 1/4 1/4		Section number 27	Township number T 23 S	Range number R 22 E
2. Distance and direction from nearest town or city: 7 MILES SOUTH OF HANSTON KS				3. Owner of well: CLELAND KOONITZ		
Street address of well location if in city:				R.R. or street: HANSTON KANSAS		
City, state, zip code: HANSTON KANSAS						
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 5-20-77 Well depth 78 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24" in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia 1 1/2 in. to 26 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 188		
5. Type and color of material		From	To	10. Screen: Manufacturer's name WA DROWN Type STEEL Dia. 1 1/2" Slot/gauze 1/8 Length 40' Set between 38 ft. and 78 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 DOWN		
BLACK TOPSOIL		0	6	11. Static water level: _____ mo./day/yr. 29 ft. below land surface Date 25-2-77		
BROWN CLAY		6	42	12. Pumping level below land surfaces: 68 ft. after 4 hrs. pumping 666 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 750 g.p.m.		
FINE SAND GETS COURSE WITH DEPTH VERY LITTLE CLAY		42	75	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
YELLOW CLAY		75	78	14. Well head completion: <input type="checkbox"/> Pitless adapter 24" Inches above grade		
RAIN BOW CLAY		78	80	15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
BRICK 75' R.R.				16. Nearest source of possible contamination: ft. 80 Direction SE Type DRAW Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
28				17. Pump: Not installed Manufacturer's name WTR Model number _____ HP 20 Volts 440 Length of drop pipe 70 ft. capacity 650 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
47' sand thick				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 243 DEAN WATER HOUSE DRILLING Business name _____ License No. _____ Address HANSTON KANSAS Signed Dean Waterhouse Date 26 Authorized representative DAVE 77		
in Alluvium						
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	2200 75 2125 TOPO					

T 23 S 22 E Sec 27 SW NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5