

JETMORE SE


T R EW sec 1/4 1/4 1/4 No.

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

AB center?

1 Location of well:	County Hodgeman	Township name Center	Fraction NE 1/4 NW 1/4	Section number 3	Town number T23S	Range number R23W
Distance and direction from nearest town or city: Street address of well location if in city: 3 1/2 Miles East of Jetmore				3 Owner of well: Address: Norman Winget Jetmore, Kansas 67854		
Locate with "X" in section below: 				Sketch map: 750 Ft From North Line 940 Ft From West Line		
2				4 Well depth: 77 ft. Date of completion Sept Well diameter 26 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Sand				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Clay				7 Casing: Material Steel Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 2 in. Diam. 16 in. to 17 ft. depth; Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth;		
Sand				8 Screen: Manufacturer Doerr Type Gravel Guard 16 Slot/gauze 3/16 Length 40 Set between 37 ft. and 77 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1 to 1		
Clay				9 Static water level: 30 ft. below land surface Date Sept		
Sand Blue				10 Pumping level below land surfaces: 25 ft. after 8 hrs. pumping 400 g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 450 g.p.m.		
BROCK 75'				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —		
30				12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
45' sat thick				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 0 ft.		
in Alluvium				14 Nearest source of possible contamination: ft. 0 Direction — Type — Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Roller Model number — HP 20 Volts 440 Length of drop pipe 70 ft. capacity 400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley TOPO 2224 75 2149				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Knoefler Bros. 130 Business name License No. — Address Jetmore, Kansas 67854 Signed Dale Knoefler Date Sept 27 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5