

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


WATER WELL RECORD
KSA 82a-1201-1215

HORSE THIEF CANYON

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

- DCA

1 Location of well:	County HODGEMAN	Township name HALLET	From NE SW SE	Section number 13	Town number 23	Range number 25
Distance and direction from nearest town or city: 6 MILES WEST AND 2 1/2 MILES SOUTH OF JETMORE			3 Owner of well: ERNEST BELTZ Address: JETMORE KANSAS			
Locate with "X" in section below: 		Sketch map:		4 Well depth: 78 ft. Date of completion 12-6-75 Well diameter 5 in.		
2		Type and color of material		From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
		TOPSOIL		0	4	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
		SANDY & LIGHT CLAY		4	12	7 Casing: Material STEEL Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 26 in. Diam. 250 lbs. WALL 26 in. to 68 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth
		CEMENTED - SAND - HARD		12	45	8 Screen: Manufacturer DESSE & LOWELL Type STYRENE Dia. 5" Slot/gauze 1/8 Length 10 Set between 68 ft. and 78 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 46 DOWN
		SOFT GREY CLAY - HARD STRIPS		45	59	9 Static water level: 61 ft. below land surface Date 12-6-75
		SANDY CLAY - THEN, COARSE SAND		59	64	10 Pumping level below land surfaces: 74 ft. after hrs. pumping 3 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 4 g.p.m.
		YELLOW CLAY		64	70	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
		BLACK SHALE		70	80	12 Well head completion: <input type="checkbox"/> Pitless adapter 26 inches above grade
		BLOCK 64'				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 11 ft.
		61				14 Nearest source of possible contamination: COWPASTURE ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		3' sat thick				15 Pump: SEE NOTE <input type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe 72 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
		in Alluvium				16 Remarks: elevation SET 1 1/4 Cylinder + WIND MILL 2500 7436 HANSTON KANS WL = 2500 - 61 = 2439 TOPO
		(use a second sheet if needed)				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERHOUSE BRILLING Business name License No. 243 Address Dean Waterhouse Signed Dean Waterhouse Date 6-13-75 Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5