

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

*NE 1/4 sec 17, T23S, R3W*

1 Location of well: County *Harvey* Township name *Burton* Fraction *NE 1/4 sec 17* Section number *17* Town number *T23S* Range number *R-3-W*

Distance and direction from nearest town or city: *2N-Y2W 2* 3 Owner of well: *James Siemens*

Street address of well location if in city: *Burton Kans.* Address: *R.R. 2 Burton Kans.*

Locate with "X" in section below: Sketch map: *NE Harvey County, KS*

4 Well depth: *34* ft. Date of completion *6-5-75*  
Well diameter *8* in.

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug  
☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☒ Domestic ☐ Public supply ☐ Industry  
☐ Irrigation ☐ Air conditioning ☐ Commercial  
☐ Test well ☐

7 Casing: Material *PVC* Height: *above* below  
Threaded ☐ Welded ☒ Surface *12* in.  
Diam. *5* in. to *34* ft. depth Weight *12* lbs./ft.  
Drive shoe? ☐ Yes ☒ No

8 Screen: Manufacturer *Curtis Tool*  
Type *PVC* Dia. *5* in.  
Slot gauge *1/32* Length *10 ft*  
Set between *24* ft. and *34* ft.  
Fittings: *1/4 - 1/4*  
Gravel pack ☒ Yes ☐ No Size range of material

9 Static water level: *6* ft. below land surface Date *6-5-75*

10 Pumping level below land surfaces:  
*7* ft. after *2* hrs. pumping *15* g.p.m.  
ft. after hrs. pumping g.p.m.  
Estimated maximum yield *25* g.p.m.

11 Water sample submitted:  
☐ Yes ☒ No Date

12 Well head completion:  
☐ Pitless adapter ☒ 12" inches above grade

13 Well grouted? ☒ Yes ☐ No  
☒ Neat cement ☐ Bentonite ☐  
Depth: From *0* ft. to *10* ft.

14 Nearest source of possible contamination:  
ft. *150* Direction *S.W.* Type *Septic*  
Well disinfected upon completion? ☒ Yes ☐ No

15 Pump: ☒ Not installed  
Manufacturer's name  
Model number HP Volts  
Length of drop pipe ft. capacity g.p.m.  
Type:  
☐ Submersible ☐ Turbine  
☐ Jet ☐ Reciprocating  
☐ Centrifugal ☐ Other

16 Remarks: elevation  
Topography:  
☐ Hill  
☒ Slope  
☐ Upland  
☐ Valley

17 Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
*Peterson Bros 138*  
Business name License No.  
Address *Box 150 Lindsay, Mo.*  
Signed *Wallace Peterson* Date *6-5-75*  
Authorized representative

*Cased 34 feet 8" 5" PVC.*

*The surrounding area is sand hills*