WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction			Section	number	Township number Range number
1. Location of well:	Harvey	1	TW 1/4	NW 1/4	م ا		
2. Distance and direction from nearest town or city: 4 miles east of Burrton Street address of well location if in city: 3. Owner of well R.R. or street: City, state, zip					. E	Equus Beds GMD Box 232 Halstead, Ks 67056	
4. Locate with "X" in section below: N							6. Bore hole dia. 4 in. Completion date 8/8/78 Well depth 105ft. 7 Cable tool X Rotary _ Driven _ Dug _ Hollow rod _ Jetted _ Bored _ Reverse rotary 8. Use: _ Domestic _ Public supply _ Industry _ Irrigation _ Air conditioning _ Stock _ Lawn _ Oil field water _ X Other 9. Casing: Material _ Height: Above or below Threaded _ Welded _ ISurface 2.23 ft. in. RMP _ PVC X _ eight _ Ibs./ft.
t→ 1 Mile → t					T	.	Dia. 2 in. to 102 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. Sch 40
5. Type and color of					From	To 4	10. Screen: Manufacturer's name
Clay, tan, brown					4	40	Type wellpoint Slot/gauze 10 Set between 102 ft. and 105 ft.
Sand & clay layers, greenish yellow					40	57	ft. andft. Gravel pack?Size range of material
Sand & a	gravel, yellow				57	70	11. Static water level: 20.82. below land surface Date 8/28/78
Clay, tan				70	75	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m.	
Sand & claylayers, tan				75	82	ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
Sand & gravel, yellow					82	85	13. Water sample submitted: mo./day/yr.
Sand & clay layers, yellow					85	98	Yes No
Sand & gravel, white					98	107	Pitless adapter Inches above grade
Clay, tan					107		With: Neat cement Bentonite _x Concrete Depth: From 0 ft. to 2 ft.
Fine sand, white					<u> </u>		Nearest source of possible contamination: ft Direction Type
Clay, gray					120	195	Well disinfected upon completion? Yes No. No. 17. Pump: Not installed
							Manufacturer's name
-							Length of drop pipe ft. capacityg.p.m.
						Type: Submersible Turbine	
(Use a second sheet if needed)						Jet Reciprocating Other	
18. Elevation: 1437 ft. Topography: Hill	19. Remarks: EB - 20B						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Equus Beds GMD Business name License No.
Slope							Address Box 232, Halstead, Ks Signed Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5