

CORRECTION(S) TO WATER WELL RECORD (WWC-5)

(to rectify lacking or incorrect information)

County: Finney

Location listed as:

Section-Township-Range: 3-23 S-34

Fraction (  $\frac{1}{4}$   $\frac{1}{4}$   $\frac{1}{4}$ ): NE SW NW

Location changed to:

30-23 S-34 W

NE SW NW

Other changes: Initial statements: \_\_\_\_\_

Changed to: \_\_\_\_\_

Comments: \_\_\_\_\_

verification method: written & legal descriptions, county map,  
water rights information in WIMAS database, and mapping tool  
on KGS website. initials: DR date: 6/23/2010

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726

to: Kansas Dept of Health & Environment, Bureau of Water, 1000 SW Jackson, Suite 420, Topeka, KS 66612-1367.

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WOLF

514

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Finney</b>	Fraction <b>NE 1/4 SW 1/4 NW 1/4</b>	Section number <b>3</b>	Township number <b>T 23 S</b>	Range number <b>R 34 E/W</b>
2. Distance and direction from nearest town or city: <b>West of Garden City on Hiway 50 to county line, 1 1/2 north.</b> Street address of well location if in city:			3. Owner of well: <b>Hollis Pettz</b> R.R. or street: <b>Deerfield, Ks. 67838</b> City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		6. Bore hole dia. <b>26</b> in. Completion date <b>6-10-75</b> Well depth <b>340</b> ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>341</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>	
					10. Screen: Manufacturer's name <b>Johnson Division</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/Length <b>20'</b> Set between <b>310</b> ft. and <b>330</b> ft. Perf: <b>135-370</b> ft. and <b>330-340</b> ft. Gravel pack? <b>yes</b> Size range of material <b>1/2" down</b>	
					11. Static water level: <input type="checkbox"/> mo./day/yr. <b>92</b> ft. below land surface Date <b>6-21-75</b>	
					12. Pumping level below land surfaces: <b>117</b> ft. after <b>2</b> hrs. pumping <b>1400</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>1400</b> g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
					14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade	
					15. Well grouted? <b>yes</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
					16. Nearest source of possible contamination: <b>N/A</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: <b>2948 (TOPO)</b>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling Co. 208</b> Business name License No. Address <b>Box 493 Garden City, Ks.</b> Signed <b>M. Minter</b> Date <b>11-13-75</b> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professional

# WINTER WILSON DRILLING CO.

INCORPORATED

Drilling  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8219 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Hollis Pettz  
Finney County  
6-16-75

Location: North  $1\frac{1}{2}$  miles on the county line, on east side  
of road

## Test #2

0	4	Top soil
4	73	Brown sandy clay
73	86	Fine to med. sand and gravel (loose)
86	95	Brown sandy clay
95	100	Fine to med. sand and gravel
100	134	Brown sandy clay, gravel streak
134	140	Fine to med. sand & gravel
140	155	Fine to med. sand & gravel, clay streak (loose)
155	177	Fine to med. sand & gravel (loose)
177	182	Brown sand, clay
182	195	Fine to med. sand & gravel (loose)
195	200	Brown sandy clay
200	236	Med. sand & gravel (loose)
236	241	Brown sandy clay
241	266	Fine to med. sand & gravel (loose)
266	275	Fine to med. sand & gravel, clay streak
275	293	Fine to med. sand & gravel, 15% clay (tight)
293	302	Brown sandy clay, a gravel streak
302	337	Fine to med. sand & gravel, mixed with white rock (little tight)
337	346	Yellow clay, little gravel streak mixed
346	349	Yellow clay
349	350	Shale

Static Water Level: 60'

T.D. 340'  
20' Screen