

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Rains Williamson
Kearny Co.
11-28-84

Location: NE 13-23-35

East of Deerfield to Finney, Kearny Co.
Line on Hwy 50. 3 Miles No. $\frac{1}{2}$ Mile West
3/4 Mile No.

Static water level 160'

Test # 1

0 4 Top soil
4 32 Brown clay
32 37 Fine to medium sand & gravel
37 41 Brown sandy clay
41 57 Fine to medium sand & gravel
57 122 Brown sandy clay
122 154 Fine to medium sand & gravel
154 176 Brown sandy clay
176 183 Fine to medium sand & gravel
183 212 Brown sandy clay
212 218 Fine to medium sand & gravel, small streak
of clay
218 224 Brown sandy clay
224 231 Brown sandy clay, small streak gravel
231 253 Brown sandy clay
253 285 Fine to medium sand & gravel, Tight
285 292 Brown sandy clay
292 299 Fine to medium sand & gravel, clay strip
299 306 Brown sandy clay
306 313 Fine to medium sand & gravel
313 330 Brown clay
330 350 Brown clay, Hard