

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.


WOLF SW

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ACA

1 Location of well:	County Kearny	Township name East Hibbard	Fraction 100 yds. S. of Pivot	Section number NE 1/4 2	Town number T 23 S	Range number R 35 W
Distance and direction from nearest town or city: 7 north of Deerfield, Ks. on cemetery road, 1/2 west, Street address of well location if in city: 3/8 south			3 Owner of well: M. R. Combs Address: Deerfield, Ks. 67838			
Locate with "X" in section below: N 		Sketch map:		4 Well depth: 254 ft. Date of completion 4-25-75 Well diameter 26 in.		
2 Type and color of material BROCK 253'				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material Steel Height: above ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 255 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 55.87 lbs./ft. 1 — in. to — ft. depth		
				8 Screen: Manufacturer Johnson Division Type Galv. Dia. 16" Slot size Length 20' Set between 180 ft. and 200 ft. Points: 135-180, 200-254 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2" down		
				9 Static water level: 105 ft. below land surface Date 4-30-75		
				10 Pumping level below land surfaces: 138 ft. after 2 hrs. pumping 654 g.p.m. 150 ft. after 4 hrs. pumping 825 g.p.m. Estimated maximum yield 800 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation Customer furnished pump. 3000 (JOPO)		
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name _____ License No. _____ Address Box 493 Garden City, Ks. Signed [Signature] Date 6-27-75 Authorized representative						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Kearny County

M. R. Combs

February 28, 1975

NE $\frac{1}{4}$ sec. 2 T. 23 R. 35 Static Water Level 105 Test # 6

Location: 100 YDS South of No. 1

0	2	Top Soil
2	37	Brown Clay
37	50	Fine to Medium Sand & Gravel (Loose)
50	67	Brown Clay
67	80	Fine to Medium Sand & Gravel 10% Clay (Loose)
80	110	Brown Clay
110	117	Fine to Medium Sand & Gravel 10% Clay (Loose)
117	135	Brown Sandy Clay
135	152	Fine to Medium Sand & Gravel (Loose)
152	179	Brown Clay
179	201	Fine to Medium Sand & Fine Gravel (loose)
201	236	Brown Sandy Clay
236	244	Fine to Medium Sand & Gravel with White Rock 15% Clay (Loose)
244	254	Brown & Yellow Clay
254	260	Shale(Hard)