

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CSD

1. Location of well:		County Kearny	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 15	Township number T 23 S R	Range number 35	
2. Distance and direction from nearest town or city: 150 Yds. north of Deerfield Street address of well location if in city:			3. Owner of well: C.C. Cattle Co. R.R. or street: Ulysses, KS 67880 City, state, zip code:				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date <u>9-30-76</u> Well depth <u>407</u> ft.		
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36,87</u> lbs./ft. Dia. <u>16</u> in. to <u>408</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			
				10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <input type="checkbox"/> Length <u>20"</u> Set between <u>360</u> ft. and <u>380</u> ft. <u>Perf: 140-360</u> and <u>380-407</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>2" Down</u>			
				11. Static water level: <input type="checkbox"/> mo./day/yr. <u>102</u> ft. below land surface Date <u>8-27-76</u>			
				12. Pumping level below land surfaces: <u>157</u> ft. after <u>3</u> hrs. pumping <u>1500</u> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.			
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade			
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
				16. Nearest source of possible contamination: <u>N/A</u> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <u>Field MC</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		(Use a second sheet if needed)					
18. Elevation:		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling 208</u> Business name <u>Box A Garden City, KS 67849</u> License No. <u>49</u> Address <u>2-24-77</u> Signed <u>[Signature]</u> Date <u>2-24-77</u> Authorized representative	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<u>3022 (TOPO)</u> <u>Customer Furnished pump.</u>					

2
3
35
15
C
SE
SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5



WOLF SW

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

C.C. CATTLE CO.
KANSAS COUNTY
7-26-76

CDD

Location: S 1/4 15-23-34 first road west of Station at
Deerfield 1/4 north 1/4 west 300 Ft. north
Static Water Level- 100'

Test #1

0	4	Top soil
4	22	Fine sand
22	50	Brown clay
50	80	Fine to med. sand and gravel
80	110	Gray clay
110	122	Fine to med. sand and gravel
122	140	Fine to med. sand and gravel 10% clay
140	172	Fine to med. sand and gravel
172	213	Blue clay
213	269	Fine to med. sand and gravel
269	277	Brown sandy clay
277	304	Fine to med. sand and gravel
304	335	Brown sandy clay
335	350	Fine to med. sand
350	365	Fine to med. sand and fine gravel
365	375	Fine to med. sand and gravel
375	407	Fine to med. sand with white rock Hard
407	414	Brown and yellow clay
414	420	Shale

T.D. 407

BRICK 413'