

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Kearney		Fraction 1/4 1/4 SW 1/4		Section number 27	Township number T 23 S R 35	Range number 35																																																			
2. Distance and direction from nearest town or city: 2 m. N Deerfield				3. Owner of well: Standley Tackett																																																					
Street address of well location if in city: Deerfield, Mo.				R.R. or street: Deerfield, Mo.																																																					
4. Locate with "X" in section below: 				6. Bore hole dia. 9 1/8 in. Completion date: 9-18-79 Well depth 374 ft.																																																					
5. Type and color of material				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																																																					
<table border="1"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr><td>Top Soil</td><td>0</td><td>8</td></tr> <tr><td>Sandy clay</td><td>8</td><td>81</td></tr> <tr><td>Clay & Sand</td><td>81</td><td>97</td></tr> <tr><td>Fine to med Sand & gravel</td><td>97</td><td>140</td></tr> <tr><td>Gray clay</td><td>140</td><td>160</td></tr> <tr><td>Fine to med Sand & gravel</td><td>160</td><td>170</td></tr> <tr><td>Blue clay</td><td>170</td><td>181</td></tr> <tr><td>Fine to med Sand & gravel</td><td>181</td><td>195</td></tr> <tr><td>Brown Sandy clay</td><td>195</td><td>200</td></tr> <tr><td>Fine to med Sand & gravel</td><td>200</td><td>223</td></tr> <tr><td>Brown Sandy clay</td><td>223</td><td>255</td></tr> <tr><td>Hard Rock</td><td>255</td><td>267</td></tr> <tr><td>Fine to med Sand</td><td>267</td><td>275</td></tr> <tr><td>Hard Rock</td><td>275</td><td>280</td></tr> <tr><td>Brown Sandy clay</td><td>280</td><td>310</td></tr> <tr><td>Fine to med Sand & gravel</td><td>310</td><td>375</td></tr> </tbody> </table>					From	To	Top Soil	0	8	Sandy clay	8	81	Clay & Sand	81	97	Fine to med Sand & gravel	97	140	Gray clay	140	160	Fine to med Sand & gravel	160	170	Blue clay	170	181	Fine to med Sand & gravel	181	195	Brown Sandy clay	195	200	Fine to med Sand & gravel	200	223	Brown Sandy clay	223	255	Hard Rock	255	267	Fine to med Sand	267	275	Hard Rock	275	280	Brown Sandy clay	280	310	Fine to med Sand & gravel	310	375	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
	From	To																																																							
Top Soil	0	8																																																							
Sandy clay	8	81																																																							
Clay & Sand	81	97																																																							
Fine to med Sand & gravel	97	140																																																							
Gray clay	140	160																																																							
Fine to med Sand & gravel	160	170																																																							
Blue clay	170	181																																																							
Fine to med Sand & gravel	181	195																																																							
Brown Sandy clay	195	200																																																							
Fine to med Sand & gravel	200	223																																																							
Brown Sandy clay	223	255																																																							
Hard Rock	255	267																																																							
Fine to med Sand	267	275																																																							
Hard Rock	275	280																																																							
Brown Sandy clay	280	310																																																							
Fine to med Sand & gravel	310	375																																																							
				9. Casing: Material PITS Height: Above ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 18 lbs./ft. Dia. 5 in. to 554 ft. depth Wall Thickness: inches or Dia. 5 in. to 554 ft. depth gage No. 32470																																																					
				10. Screen: Manufacturer's name Pitless Type PITS Dia. 5" Slot/gauze 254 Length 374' Set between 254 ft. and 374 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 8-30 ft.																																																					
				11. Static water level: 175 ft. below land surface Date 9-18-79 mo./day/yr.																																																					
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.																																																					
				13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____																																																					
				14. Well head completion: 18 Pitless adapter 18 Inches above grade																																																					
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 20 ft.																																																					
				16. Nearest source of possible contamination: 200 ft. Direction SE Type Septic Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																																																					
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																																					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Jonagan Oil 172 Business name Ingalls, KS License No. ____ Address ____ Signed M.P. Authorized representative Date 7/87																																																					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley																																																									

T 23
 R 35
 Sec 27
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5