

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.


WOLF SW

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ABD

1 Location of well:	County Kearny	Township name	Fraction SE-NW- Center of NE 1/4	Section number 28	Town number T 23 S	Range number R 35 W
Distance and direction from nearest town or city: 2 N., 2 1/4 W. of Deerfield Cemetery Street address of well location if in city:				3 Owner of well: Shirley Tillotson Address: 1018 Arapahoe Ulysses, Ks. 67880		
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 315 ft. Date of completion: 3/14-75 Well diameter 26 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
See attachment					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
BROCK 325					7 Casing: Material <u>Steel</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. _____ Weight <u>36</u> lbs./ft. _____ <u>16</u> in. to <u>315</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth	
					8 Screen: Manufacturer <u>Johnson</u> Type <u>Continuous</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>180</u> ft. and <u>200</u> ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material <u>1/4 to 1/8</u>	
					9 Static water level: <u>82</u> ft. below land surface Date <u>2-1-75</u>	
					10 Pumping level below land surfaces: <u>163</u> ft. after _____ hrs. pumping <u>1500</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade <u>12</u>	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>0</u> ft. to <u>10</u> ft.	
					14 Nearest source of possible contamination <u>None Observed</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Johnston</u> Model number <u>444C</u> HP _____ Volts _____ Length of drop pipe <u>205</u> ft. capacity <u>1500</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation <u>3015 (TOPO)</u>			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Henkle Drilling & Supply 145</u> Business name _____ License No. _____ Address <u>639 Garden City, Ks.</u> Signature <u>[Signature]</u> Date <u>4/10/75</u> Authorized Representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Mrs. Shirley Tillotson DATE 1-28-75
 STREET ADDRESS _____ TEST # 1 E.L.Hole 340 F
 CITY & STATE Ulysses, Kansas DRILLER Rector
 COUNTY Kearny QUARTER NE SECTION 28 TOWNSHIP 23 RANGE 35

LOCATION In Center of 1/4 and 20 Ft. North of Pivot Point

WELL LOCATION

%	DRILLED FOOTAGE		Description of Strata	Static Water Level
	from	Pay to		Proposed Well Depth
	0		4	Surface
	4		40	Brown clay and few sand st.
	40		100	Sand fine med. coarse; med., small gravel and fine sandy clay
	100		116	Sand med. coarse, med., small and small gravel. Loose. Used lots of water..
	116		121	Brown sandy clay
35	121	18	138	Sand fine med. coarse, small coarse and small gravel. Real loose. Used lots of water.
60	138	62	200	Sand fine med. coarse, small coarse, med. small gravel and fine sandy clay st. Loose. Took little water.
65	200	9	209	Sand, med. coarse, small coarse, small gravel. Few tiny white rock. Loose. Used lots of water.
	209		220	Brown clay and sand st.
65	220	8	228	Sand fine med. coarse, med. small gravel. Real loose. Used lots of water.
	228		240	Brown clay, caliche and few sand st.
50	240	5	245	Sand fine med. coarse; med., small gravel.
	245		257	Brown clay and limrock st.
45	257	8	265	Brown sandy clay and sand fine to med. coarse
75	265	40	305	Sand fine med. coarse; small coarse; small gravel. small white rock. Loose. Used lots of water. Good
55	305	7	312	Brown sandy clay, sand, med. coarse, small gravel. Limerock. Used water.
	312		325	Brown clay and sand st.
	325		330	Soapstone and limestone
	330		340	Shale and very hard stringers.
		157		Set up face west Pit on the north.
				TOTAL DEPTH OF WELL 315 Ft.

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
 PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311
 TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****