

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.


WOLF SW

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

331

1 Location of well:	County Kearny	Township name	Fraction <u>SE-NW</u> Center of NW $\frac{1}{4}$	Section number 28	Town number T 23 S	Range number R 35 W
Distance and direction from nearest town or city: 1 3/4 N. 2 3/4 W. of Deerfield Cemetery Road. Street address of well location if in city:				3 Owner of well: Shirley Tillotson Address: 1018 Arapahoe Ulysses, Kansas 67880		
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		4 Well depth: <u>260</u> ft. Date of completion: <u>3-4-75</u> Well diameter <u>26</u> in.	
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
See attachment					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
BROCK 257'					7 Casing: Material <u>Steel</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. _____ Weight <u>36</u> lbs./ft. <u>16</u> in. to <u>260</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth	
					8 Screen: Manufacturer <u>Johnson</u> Type <u>Continuous</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>170</u> ft. and <u>190</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/8</u>	
					9 Static water level: <u>84</u> ft. below land surface Date <u>2-4-75</u>	
					10 Pumping level below land surfaces: <u>204</u> ft. after _____ hrs. pumping <u>1217</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					12 Well head completion: <u>12</u> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>0</u> ft. to <u>10</u> ft.	
					14 Nearest source of possible contamination: <u>None Observed</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Johnston</u> Model number <u>14AE</u> HP _____ Volts _____ Length of drop pipe <u>225</u> ft. capacity <u>1200</u> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation			17 Water well contractor's certification:			
3025 (TOPO)			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name _____ License No. _____ Address: <u>Garden City, Ks. Box 368</u> Signature: <u>Richard Henkle</u> Date: <u>4-10-75</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope Flat <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

**DRILLERS TEST LOG**

CUSTOMERS NAME Mrs. Shirley Tillotson DATE 1-29-75  
 STREET ADDRESS \_\_\_\_\_ TEST # 1 E.L.Hole 280  
 CITY & STATE Ulysses, Kansas DRILLER Rector  
 COUNTY Kearny QUARTER NW SECTION 28 TOWNSHIP 23 RANGE 35

LOCATION In Center of 1/4 and 20 Ft. North of Pivot Point

Samples are in on this test.

WELL LOCATION

%	DRILLED FOOTAGE		Description of Strata	Static Water Level
	from	Pay to		Proposed Well Depth
	0		4	Top soil
	4		60	Brown sandy clay and fine sand
	60		95	Sand fine med. coarse, small coarse, med., small gravel.
	95		100	Brown sandy clay
	100		109	Sand and gravel.
	109		122	Brown sandy clay
	122		139	Brown clay, caliche and sand st.
40	139	6	145	Sand fine med. coarse, few, med. small gravel. Loose. Took water.
	145		160	Brown clay and caliche
45	160	20	180	Sand fine to med. coarse, small coarse, med., small gravel. Very fine clay st. Used waer.
60	180	36	210	Sand, med. coarse, med., small, small gravel. white rock and few clay st. Loose. Used lots of water.
	210		220	Brown clay
60	200	5	225	Sand fine med. coarse, small coarse, med., small gravel. Few, tiny white rock. Loose. Took water.
	225		232	Brown clay
65	232	25	257	Fine sand med. coarse; small coarse, few, med., small gravel and brown sandy clay and few, small white rock Used lots of water.
	257		272	Soapstone, yellow clay and brown clay
	272		280	Shale
		92		Set up facing west. Pit on the north.
				TOTAL DEPTH OF WELL <u>260</u> Ft.