


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 6	Township number T 23 S R 36	Range number 11W
2. Distance and direction from nearest town or city: 10 north of Lakin; Street address of well location if in city: 2 west, 1 south, 1/2 west			3. Owner of well: Jay D. London R.R. or street: City, state, zip code: Deerfield, Ks. 67838		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 9-15-76 Well depth 180 ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material steel Height: Above surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 181 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>
					10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20' Set between 150 ft. and 170 ft. Perf: 120-150 ft. and 170-180 ft. Gravel pack? yes Size range of material 1/2" down
					11. Static water level: <input type="checkbox"/> mo./day/yr. 113 ft. below land surface Date 6-29-76
					12. Pumping level below land surfaces: 158 ft. after 3 hrs. pumping 550 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 550 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> 12 inches above grade
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - US Pump Model number 10JHC HP 60 Volts <input type="checkbox"/> Length of drop pipe 170 ft. capacity 500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 3159 (TOPO)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MINTER-WILSON DELG. CO. 208 Business name License No. Address Box A Garden City, Ks. Signed <i>[Signature]</i> Date 12-20-76 Authorized representative		

T 23 R 36 S 11W
Sec 6 SE 1/4 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

LEOTI 3 SE

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Jay Landon
Kearny County
6-16-76

Location: 60' West of #6

Test #7

- 0 1 Top soil
- 1 16 Brown clay
- 16 31 Med. to coarse gravel (loose)
- 31 50 Brown clay
- 50 63 Fine to med. sand & gravel (loose)
- 63 74 Brown clay
- 74 82 Fine to med. sand & gravel, 10% clay (loose)
- 82 93 Brown clay
- 93 138 Fine to med. sand & gravel (loose)
- 138 141 Brown clay
- 141 170 Fine to med. sand & gravel (loose)
- 170 176 Brown & yellow clay
- 174 180 Shale (hard)

Static Water Level: 102

T.D. 180' XXX

BROCK 174'

DDIS