


LEOTI 3 SW

USE TYPEWRITER OR BALL POINT PEN - PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment - Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ACA

1. Location of well:		County KEARNY	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 4	Township number T 23 S	Range number R 37 W
2. Distance and direction from nearest town or city: 6 west 9 1/2 north 1/2 west 1/4 north of Lakin Street address of well location if in city:				3. Owner of well: Ed Wiatt R.R. or street: Lakin, Ks. 67860 City, state, zip code:		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 26 in. Completion date 4-16-76 Well depth 240 ft.		
5. Type and color of material				From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
BROCK 232						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 2 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250
						10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16 in. Slot/gauze 100 Length 20 ft. Set between 213 ft. and 233 ft. Perf. 190-213 ft. and 233-240 ft. Gravel pack? yes Size range of material: 1/2" Down
						11. Static water level: <input type="checkbox"/> mo./day/yr. 191 ft. below land surface Date 2-27-76
						12. Pumping level below land surfaces: 227 ft. after 3 hrs. pumping 450 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 450 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: Manufacturer's name Goulds US Pumps <small>Not installed</small> Model number 10JHC HP 60 Volts <input type="checkbox"/> Length of drop pipe 230 ft. capacity 450 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name O. Box A Garden City, Ks Address <input type="checkbox"/> Signed [Signature] Date 7-6-76 Authorized representative
18. Elevation:		19. Remarks: 3278 (TUPO)				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

23376-4 NE SW NE
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

ED WIATT
Kearney County
2-2-76

Location NE 4-23-37
From Lakin, 6 Miles West, 10 Miles North, $\frac{1}{2}$
West, $\frac{1}{4}$ South

Static Water Level 185'

Test #

0	2	Top Soil
2	14	Brown Clay
14	42	Fine To Med. Sand & Gravel
42	46	Brown Sandy Clay
46	64	Fine To Med Sand & Gravel
64	105	Brown Sandy Clay
105	121	Fine To Med. Sand & Gravel
121	128	Brown Sandy Clay
128	172	Fine To Med. Sand & Gravel
172	179	Brown Clay
179	186	Fine To Med. Sand & Gravel
186	200	Med. Sand & Gravel
200	209	Fine To Med. Sand & Gravel
209	218	Brown Sandy Clay
218	232	Fine To Med. Sand & Gravel, Mixed White Rock (Loose)
232	238	Yellow Clay Mixed With Rock (Hard)
238	240	Shale

190 Plain

23 Perf.

20 Screen

7 Perf.

TD 240 20 Screen