

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

LEOTI 3 SE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DCD

1. Location of well:		County Kearny	Fraction SE 1/2 SW 1/4 SE 1/4	Section number 26	Township number T 23 S	Range number R 37 E
2. Distance and direction from nearest town or city: Street address of well location if in city: 4th NW - IN Lakin				3. Owner of well: R.R. or street: City, state, zip code: Tom Wright III Lakin, Ks. 67860		
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile West of C of S 80				6. Bore hole dia. 16 in. Completion date _____ Well depth 287 ft. 7/19/76		
5. Type and color of material				7. Cable tool <input checked="" type="checkbox"/> Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored _____ Reverse rotary _____		
				8. Use: _____ Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____		
				9. Casing: Material Steel Height above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 36.86 lbs./ft. Dia. 16 in. to 287 ft. depth; Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth; gage No. 219		
				10. Screen: Manufacturer's name _____ Lakewood Type Millslot Dia. 16 Slot/gauge 1/8 Length 761 Set between 211 ft. and 287 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/4 - 1/2		
				11. Static water level: _____ mo./day/yr. 238 ft. below land surface Date 6/27/76		
				12. Pumping level below land surfaces: 277 ft. after 12 hrs. pumping 450 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 450 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
				14. Well head completion: _____ Pitless adapter 12 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete _____ Depth: From 0 ft. to 10 ft. MHC		
				16. Nearest source of possible contamination: NA ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes _____ No		
				17. Pump: _____ Not installed Manufacturer's name Worthington Model number 48-121-51HP Volts _____ Length of drop pipe 270 ft. capacity 540 g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ _____ Jet _____ Reciprocating _____ _____ Centrifugal _____ Other _____		
				(Use a second sheet if needed)		
18. Elevation: Topography: _____ Hill <input checked="" type="checkbox"/> Slope _____ Upland _____ Valley		19. Remarks: 3263 (TJPO) BROCK 280'		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply, Inc. 136A Business name License No. _____ 402 Nth 3rd Address Garden City, Ks. 67846 Signed Bob O'Neil Date 8-7-76 Authorized representative		

T 23 S R 37 E Sec 26 NW 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5