

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 26	Township number T 23 S R 37	Range number E/W
2. Distance and direction from nearest town or city: 4 mi West & 6 mi North of Lakin Street address of well location if in city:			3. Owner of well: Tom Wright III Box 108 R.R. or street: Lakin City, state, zip code: Wendell, Kansas 67857		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 3/4 in. Completion date 5-10-77 Well depth 295 ft.	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material Plastic Height Above or below Threaded <input type="checkbox"/> Welded Glue Surface 2 1/2 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 295 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. Sch 40	
				10. Screen: Manufacturer's name Jesse Lowell Type Plastic Dia. 5" Slot/gauze 1/16 Length 20 Set between 275 ft. and 295 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 3/16	
Clay		0	20	11. Static water level: _____ mo./day/yr. 260 ft. below land surface Date 5-10-77	
Sand & Gravel		20	60	12. Pumping level below land surfaces: 270 ft. after 1 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 25 g.p.m.	
Fine Sand		60	140	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Clay		140	160	14. Well head completion: _____ <input type="checkbox"/> Pitless adapter 18 Inches above grade	
Fine Sand		160	200	15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 12 ft. to 25 ft.	
Sand & Gravel		200	220	16. Nearest source of possible contamination: ft. 500 Direction W Type House Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Med Sand & Clay Streaks		220	240	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Sandy Clay		240	280		
Med sand, sand & Gravel & Clay		280	298		
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks: Placed own Pump in Well.			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				High Plains Drilling & Supply 136B Business name Address 409 N 3rd Garden City, KS Signed Arthur W. Dickerson Date 7/1/77 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5