

WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
COUNTY: HAMILTON	SW 1/4 SE 1/4 SE 1/4	16	T 23 S	R 40 W

Distance and direction from nearest town or city street address of well if located within city?
FROM SYRACUSE ON 50 HIGHWAY 1 EAST, 4 NORTH AND 1/2 EAST

2 WATER WELL OWNER:	BIZONA, BOYD	Board of Agriculture, Division of Water Resources Application Number:
RR#, St. Address, Box # :	BOX 687	
City, State, ZIP code :	SYRACUSE, KS 67878-	

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL 496	ELEVATION: 0												
	Depth(s) Groundwater Encountered	1. 0 ft. 2. 0 ft. 3. 0 ft.												
	WELL'S STATIC WATER LEVEL 322 ft. below land surface measured on no/day/yr 05/09/96	Pump test data: Well water was 0 ft. after 0 hours pumping 0 gpm												
	Estimated Yield 20 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm													
<table border="1"> <tr> <td>1</td> <td>NW</td> <td>NE</td> </tr> <tr> <td>2</td> <td></td> <td></td> </tr> <tr> <td>3</td> <td></td> <td></td> </tr> <tr> <td>4</td> <td>SW</td> <td>SE</td> </tr> </table>	1	NW	NE	2			3			4	SW	SE	Bore Hole Diameter 8 in. to 496 ft. and in. to 0 ft.	
	1	NW	NE											
2														
3														
4	SW	SE												
WELL WATER TO BE USED AS: DOMESTIC														
Was a chemical/bacteriological sample submitted to department? No : If yes, no/day/yr sample was submitted Water well disinfected? Yes														

5 TYPE OF BLANK CASING USED: PVC	CASING JOINTS: GLOED
Blank casing diameter 5 in. to 496 ft., Dia in. to 0 ft., Dia in. to 0 ft.	
Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21 17	
TYPE OF SCREEN OR PERFORATION MATERIAL: PVC	
SCREEN OR PERFORATION OPENINGS ARE: SAW CUT	

SCREEN PERFORATED INTERVALS:	From 430 ft. to 490 ft., From 0 ft. to 0 ft.
GRAVEL PACK INTERVALS:	From 0 ft. to 0 ft., From 0 ft. to 0 ft.
	From 30 ft. to 496 ft., From 0 ft. to 0 ft.
	From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE	
Grout intervals: From 0 ft. to 30 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.	
What is the nearest source of possible contamination: ABANDONED WELL	
Direction from well? NORTH	How many feet? 15

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	12	TOPSOIL CLAY			
12	40	FINE SAND COARSE SAND ROCK LAYERS			
40	60	FINE - MED SAND			
60	78	MED-COARSE SAND SMALL GRAVEL			
78	82	LIMESTONE IN LAYERS			
82	100	MED-COARSE SAND SMALL GRAVEL CLAY			
100	115	CLAY			
115	380	BLUE SHALE			
380	396	SANDSTONE			
396	404	ROCK LAYERS			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed under my jurisdiction and was completed on (no/day/year) 05/10/96 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (no/day/yr) 05/30/96 under the business name of JOB'S WELL SERVICE, INC. by (signature) <i>Judith Critt</i>
--

(Continued)

WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
COUNTY: HAMILTON	SW 1/4 SE 1/4 SE 1/4	16	T 23 S	R 40 W

2 WATER WELL OWNER:	BIZONA, BOYD	Board of Agriculture, Division of Water Resources Application Number:
RR#, St. Address, Box # :	BOX 687	
City, State, ZIP code :	SYRACUSE, KS 67878-	

FROM	TO	LITHOLOGIC LOG
404	496	SANDSTONE