


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

DBA

1 Location of well:	County <b>Hamilton</b>	Township name	Fraction <b>NE<math>\frac{1}{4}</math>, NW<math>\frac{1}{4}</math>, SE<math>\frac{1}{4}</math></b>	Section number <b>26</b>	Town number <b>T 23 S</b>	Range number <b>R 42 W</b>
Distance and direction from nearest town or city: <b>8<math>\frac{1}{2}</math> W. &amp; <math>\frac{1}{2}</math> N. of Syracuse</b> Street address of well location if in city:				3 Owner of well: <b>Murlin Carter</b> Address: <b>505 N. Gates Syracuse, KS</b>		
Locate with "X" in section below: N  W E S 1 Mile		Sketch map: <b>Well Drilled 7-10-75</b>		4 Well depth: <b>65</b> ft. Date of completion <b>8-8-75</b> Well diameter <b>26</b> in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
See Attached				7 Casing: Material <b>Steel</b> Weight: <b>above</b> /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. Weight <b>36</b> lbs./ft. <b>16</b> in. to <b>65</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth		
				8 Screen: Manufacturer <b>Johnson</b> Type <b>Continuous</b> Dia. <b>16"</b> Slot/gauze <b>.150</b> Length <b>20'</b> Set between <b>42</b> ft. and <b>62</b> ft. $\frac{1}{4}$ to Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/8"</b>		
BROOK 62'				9 Static water level: <b>55</b> ft. below land surface Date <b>8-8-75</b>		
				10 Pumping level below land surfaces: <b>55</b> ft. after ___ hrs. pumping <b>475</b> g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield ___ g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___		
				12 Well head completion: <b>12</b> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> ___ Depth: From <b>0</b> ft. to <b>10</b> ft.		
				14 Nearest source of possible contamination: <b>none observed</b> ft. ___ Direction ___ Type ___ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ___ Model number ___ HP ___ Volts ___ Length of drop pipe ___ ft. capacity ___ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drilling &amp; Supply</b> 145 Business name License No. ___ Address <b>Box 639 Garden City, KS</b> Signed <b>A.A. Rauscher</b> Date <b>8-28-75</b> Authorized representative		
16 Remarks: elevation <b>3311 (TOPO)</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley <b>Flat</b>						

