

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Hamilton	Fraction NW 1/4 NE 1/4 SE 1/4	Section number 21	Township number T 23 S S R 43 W E/W	Range number
2. Distance and direction from nearest town or city: 1 1/2 mi. W, & 3/4 S. of Coolidge, Kans.			3. Owner of well: Gene Hammit		
Street address of well location if in city:			R.R. or street:		
4. Locate with "X" in section below:			City, state, zip code: Holly, Co. 81047		
Sketch map: 			6. Bore hole dia. <u>30</u> in. Completion date _____ Well depth <u>50</u> ft. <u>8-25-78</u>		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>steel</u> Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP _____ PVC _____ Weight <u>40</u> lbs./ft. Dia. <u>16</u> in. to <u>30</u> ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. <u>219</u>		
5. Type and color of material			From	To	10. Screen: Manufacturer's name _____
Top soil & clay			0	8	Johnson Screen Co.
Sand & Gravel			8	49	Type <u>Screen</u> Dia. <u>16</u>
Shale			49	50	Slot/gauze _____ Length <u>20</u>
					Set between <u>30</u> ft. and <u>50</u> ft.
					_____ ft. and _____ ft.
					Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>3/4</u>
					11. Static water level: _____ mo./day/yr.
					<u>9</u> ft. below land surface Date <u>8-23-78</u>
					12. Pumping level below land surfaces:
					<u>45</u> ft. after <u>2</u> hrs. pumping <u>1500</u> g.p.m.
					_____ ft. after _____ hrs. pumping _____ g.p.m.
					Estimated maximum yield <u>1500</u> g.p.m.
					13. Water sample submitted: _____ mo./day/yr.
					Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
					14. Well head completion:
					<input type="checkbox"/> Pitless adapter <u>12</u> inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> yes
					With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete
					Depth: From <u>0</u> ft. to <u>6</u> ft.
					16. Nearest source of possible contamination:
					ft. _____ Direction _____ Type <u>None</u>
					Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
					17. Pump: <input checked="" type="checkbox"/> Not installed
					Manufacturer's name _____
					Model number _____ HP _____ Volts _____
					Length of drop pipe _____ ft. capacity _____ g.p.m.
					Type:
					<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine
					<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating
					<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:			20. Water well contractor's certification:		
19. Remarks:			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
River bottom			Ark Valley Pump & Supply 123		
Topography:			Business name _____ License No. _____		
<input type="checkbox"/> Hill			Address <u>Box 235 Hollym Co. 81047</u>		
<input type="checkbox"/> Slope			Signed <u>Gene Hammit</u> Date <u>9-20-78</u>		
<input type="checkbox"/> Upland			Authorized representative		
<input type="checkbox"/> Valley					

23 430 21 NW NE SE
 T R E Sec 1/4 1/4 2-7-4