USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

PRINT CLEARLY.		WATER WELL RE KSA 82a-1201-	-	Envir (Wate	as Department of Health and conment-Division of Environment er well Contractors) ka, Kansas 66620
1. Location of well:	County	Fraction	Section number	Township number	Range number
	Hamilton	SW 1/4 SW 1/4 NW 1/4	22	т 2 3 s	R 23 EM
2. Distance and direction from nearest town or city: 1 mi. W. & $\frac{1}{2}$ S. 3. Owner of well: Gene Hammit					
Street address of well location if in city: Of Coolidge, Kans. R.R. or street: City, state, zip code: Holly, Colorad					B 1047
4. Locate with "X" in N	n section below:	Sketch map:		6. Bore hole dia. <u>26</u> in. Well depth <u>53</u> ft.	Completion date 4-30-76
NW	 NE			7 Cable tool Rotary Hollow rod Jetted	Driven Dug Bored X Reverse rotory
X X SW	E				r conditioning Stock I field water Other Height: Above or testor

HOUSE COST

, = 11114 114 00 2 124	3. Owner of well:	Gene Hammit	
Street address of well location if in city: Of Coolidge, Kans.	R.R. or street:		
	City, state, zip code:	Holly, Colorado 81047	
4. Locate with "X" in section below: Sketch map:		6. Bore hole dia. 26 in. Completion date Well depth 53 ft. 4-30-76	
- NW NE X		7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary 8. Use: Domestic Public supply Industry	
≥ "		X Irrigation Air conditioning Stock Lawn Oil field water Other 9. Casing: Material Steel Height: Above or testow Threaded Welded X Surface 12 in. RMP PVC Weight 140 lbs./ft.	
1 Mile ————	Dia. 10 in. to 33 ft. depth Wall Thickness: inches or		
5. Type and color of material	From To	Dia in. to ft. depth gage No	
Top soil & Clay	0 11	W. A. Brown Type Free Flo Dig 16	
Sand & Gravel	11 52	Slot/gauze Gauze Length 20 ft. Set between 33 ft. and 53 ft.	
Shale	52 53	ft. andft. Gravel pack? <u>Yes</u> Size range of material <u>3/4</u>	
BROCK 52		11. Static water level: mo./day/yr. 11 ft. below land surface Date 4-15-76	
		12, Pumping level below land surfaces: 40 17 18 19 19 19 19 19 19 19 19 19	
		1 ft. after 2 hrs. pumping 2000 g.p.m.	
		13. Water sample submitted: mo./day/yr.	
		14. Well head completion:	
		Pitless adapter 12 Inches above grade 15. Well grouted? Ves	
		With: Neat cement X Bentonite Concrete Depth: From ft. to ft.	
		16. Nearest source of possible contamination: None ft Direction Type	
		Well disinfected upon completion? Yes X No 17. Pump: Not installed	
		Manufacturer's name Layne	
		Length of drop pipe 50 ft. capacity 2000 p.p.m.	
		Submersible X Turbine	
(Use a second sheet if needed)			
18. Elevation: 19. Remarks: Machine leveled		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report	
Topography:	is true to the best of my knowledge and belief. ARK VALLEY PUMP & SUPPLY 123		
Slope	Business name Address Box 235 Helly Colo.		
Upland Valley		Signed Authorized representative Date 5-24	