

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WELL 35W

BBB

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Hamilton	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 25	Township number T 23 S R 43	Range number 43
2. Distance and direction from nearest town or city: 1 mi. South & 2 east of Coolidge, Ks.			Owner of well: Bill Lowe			
Street address of well location if in city:			R.R. or street:			
			City, state, zip code: Holly, Colo. 81047			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date _____ Well depth 91 ft. 5-10-77		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material steel Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 40 lbs./ft. Dia. 16 in. to 41 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 219		
Top soil & clay		0	7	10. Screen: Manufacturer's name _____ W. A. Brown Type Free-flo Dia. 16 Slot/gage xxx Length 50 Set between 41 ft. and 91 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/4		
Sand & Gravel		7	88	11. Static water level: _____ mo./day/yr. 7 ft. below land surface Date 4-10-77		
Shale (blue)		88	91	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield Not tested g.p.m.		
BROOK 88'				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type None Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ark Valley Pump & Supply 123 Business name License No. _____ Address Box 235 Holly, Colo. Signed [Signature] Date _____ Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		3330 (top)				

T
R
S
W
E
N
Sec
1/4 1/4 1/4 1/4
23 43 25
NEW RECORD