


1 LOCATION OF WATER WELL: County: Reno		Fraction: SW 1/4 SW 1/4 NE 1/4	Section Number: 16	Township Number: T 23 S	Range Number: R 5 E																														
Distance and direction from nearest town or city street address of well if located within city? 3401 E. 4th Street																																			
2 WATER WELL OWNER: Eaton Corporation RR#, St. Address, Box #: Eaton Center City, State, ZIP Code: Cleveland, Ohio 44114-2584			Board of Agriculture, Division of Water Resources Application Number:																																
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: <div style="text-align: center;">  </div>		4 DEPTH OF COMPLETED WELL: 30.0 ft. ELEVATION: Depth(s) Groundwater Encountered 1. 12.0 ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL 12.0 ft. below land surface measured on mo/day/yr 10/26/88 Pump test data: Well water was ft. after hours pumping gpm Est. Yield gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter 10.0 in. to 30.0 ft., and in. to ft. WELL WATER TO BE USED AS: <div style="display: flex; justify-content: space-between;"> <div> 5 Public water supply 1 Domestic 2 Irrigation </div> <div> 6 Oil field water supply 3 Feedlot 4 Industrial </div> <div> 8 Air conditioning 9 Dewatering 7 Lawn and garden only </div> <div> 11 Injection well 12 Other (Specify below) 10 Monitoring well </div> </div> Was a chemical/bacteriological sample submitted to Department? Yes.....No X If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes No X																																	
5 TYPE OF BLANK CASING USED: <div style="display: flex; justify-content: space-between;"> <div> 1 Steel 2 PVC Blank casing diameter 4.0 in. to 10.0 ft., Dia Casing height above land surface 12 in., weight lbs./ft. Wall thickness or gauge No. 40 </div> <div> 3 RMP (SR) 4 ABS 5 Wrought iron 6 Asbestos-Cement 7 Fiberglass 8 Concrete tile 9 Other (specify below) Casing joints: Glued Clamped Welded Threaded X </div> </div> TYPE OF SCREEN OR PERFORATION MATERIAL: <div style="display: flex; justify-content: space-between;"> <div> 1 Steel 2 Brass SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot 2 Louvered shutter </div> <div> 3 Stainless steel 4 Galvanized steel 3 Mill slot 4 Key punched </div> <div> 5 Fiberglass 6 Concrete tile 5 Gauzed wrapped 6 Wire wrapped 7 Torch cut </div> <div> 8 RMP (SR) 9 ABS 8 Saw cut 9 Drilled holes 10 Other (specify) </div> <div> 11 Other (specify) 12 None used (open hole) 11 None (open hole) </div> </div> SCREEN-PERFORATED INTERVALS: From 10.0 ft. to 30.0 ft., From ft. to ft. From ft. to ft., From ft. to ft. GRAVEL PACK INTERVALS: From 8.0 ft. to 30.0 ft., From ft. to ft. From ft. to ft., From ft. to ft.																																			
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grout Intervals: From 8.0 ft. to 0 ft., From ft. to ft., From ft. to ft. What is the nearest source of possible contamination: <div style="display: flex; justify-content: space-between;"> <div> 1 Septic tank 2 Sewer lines 3 Watertight sewer lines 4 Lateral lines 5 Cess pool 6 Seepage pit </div> <div> 7 Pit privy 8 Sewage lagoon 9 Feedyard 10 Livestock pens 11 Fuel storage 12 Fertilizer storage 13 Insecticide storage </div> <div> 14 Abandoned water well 15 Oil well/Gas well 16 Other (specify below) Solvent Storage How many feet? ~1500 ft. </div> </div> Direction from well? Northeast																																			
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> <th>FROM</th> <th>TO</th> <th>PLUGGING INTERVALS</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>11.0</td> <td>Silty Clay: Dark Greyish Brown</td> <td></td> <td></td> <td></td> </tr> <tr> <td>11.0</td> <td>13.0</td> <td>Sandy Clay: Dark Greyish Brown</td> <td></td> <td></td> <td></td> </tr> <tr> <td>13.0</td> <td>30.0</td> <td>Silty Sand: Greyish, Reddish Brown</td> <td></td> <td></td> <td></td> </tr> <tr> <td colspan="6" style="height: 100px; vertical-align: bottom;"> Grout and casing variance granted 11/22/88 by Larry Plummer. </td> </tr> </tbody> </table>						FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS	0	11.0	Silty Clay: Dark Greyish Brown				11.0	13.0	Sandy Clay: Dark Greyish Brown				13.0	30.0	Silty Sand: Greyish, Reddish Brown				Grout and casing variance granted 11/22/88 by Larry Plummer.					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS																														
0	11.0	Silty Clay: Dark Greyish Brown																																	
11.0	13.0	Sandy Clay: Dark Greyish Brown																																	
13.0	30.0	Silty Sand: Greyish, Reddish Brown																																	
Grout and casing variance granted 11/22/88 by Larry Plummer.																																			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was 1 constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 10/13/88 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 496 This Water Well Record was completed on (mo/day/yr) 11-9-88 under the business name of DAVID DANIELS by (signature) <i>David Daniels</i>																																			