

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Reno		Fraction SE 1/4 SW 1/4 SE 1/4		Section number 2	Township number T 23	Range number S 5 R 5
2. Distance and direction from nearest town or city: 1 1/2 east of Hutchinson on 17th street Street address of well location if in city:				3. Owner of well: Rick Gagnebin R.R. or street: RR #4 City, state, zip code: Hutchinson Kansas 67501		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 12 3/4 in. Completion date 12/17/78 Well depth 74 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From To		9. Casing: Material pl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 2.17 lbs./ft. Dia. 6 in. to 74 ft. depth Wall Thickness: inches as Dia. 6 in. to 74 ft. depth gage No. 125		
				10. Screen: Manufacturer's name sunflower plastic Type pl Dia. 6 Slot/gauze .065 Length 20 ft Set between 54 ft. and 74 ft. Gravel pack? yes Size range of material 1/4-1		
				11. Static water level: 25 ft. below land surface Date 12/15/78		
				12. Pumping level below land surfaces: 40 ft. after 2 hrs. pumping 12 g.p.m. ft. after 2 hrs. pumping 12 g.p.m. Estimated maximum yield 14 g.p.m.		
				13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 12/15/78		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
				16. Nearest source of possible contamination: sewer ft. 75 Direction south Type line Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydra Well Contractors 351 Business name License No. Address RR #5 Hutchinson Kansas Signed Harry Apple Date 12/17/78 (Authorized representative)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Cutmen knows that installation of concrete slab is regulation				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5