

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Reno	Fraction W 1/4 SW 1/4 NE 1/4	Section number 6	Township number T 23 S	Range number R 5 E
2. Distance and direction from nearest town or city: 2504 Nevada Hutchinson			3. Owner of well: Jayhawk Realty Co. R.R. or street: S 10 E. 17th City, state, zip code: Hutchinson, Kan 67501		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 8-12-76 Well depth 30 ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input checked="" type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Lt brown sandy clay		7 11		9. Casing: Material Plas Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.	
fine gravel		11 14		Dia. 6 in. to 30 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1175	
medium gravel		14 30		10. Screen: Manufacturer's name J&L Type RMP Dia. 6" Slot/gauze 1/8 hole Length 10' Set between 20 ft. and 30 ft. ft. and <input type="checkbox"/> ft.	
				Gravel pack? NO Size range of material <input type="checkbox"/>	
				11. Static water level: <input type="checkbox"/> mo./day/yr. 18 ft. below land surface Date 8-12-76	
				12. Pumping level below land surfaces: 18 1/2 ft. after 1 hrs. pumping 20 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
				14. Well head completion: basement floor Pitless adapter 12 inches above floor	
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. below floor	
				16. Nearest source of possible contamination: SOLID SEWER ft. 30 Direction NW Type SOLID SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		Well located in basement		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Price Water Well 193 Business name RR3 Hutchinson License No. <input type="checkbox"/> Address John Davenport Date 7-21-77 Signed <input type="checkbox"/> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5