

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction SE 1/4 NE 1/4 SE 1/4	Section number 12	Township number T 23 S R 5 E	Range number 5
2. Distance and direction from nearest town or city: 3 mi E Street address of well location if in city: 1/2 N of Hutchinson, KS			3. Owner of well: Fred Bowlinger R.R. or street: 31 Random Rd City, state, zip code: Hutchinson, KS 67501			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 2-9-76 Well depth 42 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Topsoil / sandy		0		3		9. Casing: Material PLST Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 14 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 185 lbs./ft. Dia. 6 in. to 42 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>
Sand + clay yellow		3		7		10. Screen: Manufacturer's name Jess + Howell Type RMP Dia. 6" Slot gauge 3/32 Length 20' Set between 22 ft. and 42 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.
Blue + gray clay		7		16		Gravel pack? <input checked="" type="checkbox"/> Size range of material #6-1/2
Sand - fine brown		16		20		11. Static water level: <input type="checkbox"/> mo./day/yr. 16 ft. below land surface Date 2-9-76
Clay yellow		20		23		12. Pumping level below land surfaces: 30 ft. after 1 hrs. pumping 20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 2.5 g.p.m.
Sand fine brown		23		36		13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
Clay yellow		36		39		14. Well head completion: <input type="checkbox"/> Pitless adapter 14 inches above grade
Sand fine yellow		39		42		15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 2 ft. to 12 ft.
						16. Nearest source of possible contamination: ft. 78 Direction W Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed. Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well 137 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Hutchinson, KS Signed Joe Miller Date 2-9-76 Authorized representative
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Owner will place cement around top of well.				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5